

## ChemRisk/Shonka Research Associates, Inc., Document Request Form

#17

(This section to be completed by subcontractor requesting document)

T. Bennett

Requestor

1 1034A Document Center

Document Center (is requested to provide the following document)

Date of request 7/17/95

Expected receipt of document 8/11/95

Document number

Date of document 8/47-12/47

Title and author (if document is unnumbered)

Cascade Services Department Process Laboratory Radiation Group  
Health Survey Report

→ Please copy only up to the first yellow stickie

(This section to be completed by Document Center)

Date request received

7/18/95

Date submitted to ADC

7/19/95

Date submitted to HSA Coordinator

7/18/95

(This section to be completed by HSA Coordinator)

Date submitted to CICO

7/17/95

7/31/95

Date received from CICO

7/31/95

8/3/95

Date submitted to ChemRisk/Shonka and DOE

8/9/95

(This section to be completed by ChemRisk/Shonka Research Associates, Inc.)

Date document received

Signature

#2547

EXTRACT FROM FOLDER CONTAINING PROCESS DIVISION SURVEYS  
(1947)

Compiled by  
S. G. Thornton  
Environmental Management Division  
OAK RIDGE K-25 SITE  
for the Health Studies Agreement

July 1995

Oak Ridge K-25 Site  
Oak Ridge, Tennessee 37831-7314  
managed by  
LOCKHEED MARTIN ENERGY SYSTEMS, INC.  
for the U.S. DEPARTMENT OF ENERGY  
under Contract DE-AC05-84OR21400

UNCLASSIFIED

This document has been approved for release  
to the public by:

Sam W. Hall for A.S. Oist 8/2/95  
Technical Information Officer Date  
Oak Ridge K-25 Site

Classification changed to \_\_\_\_\_  
(level and category)

SG Thornton 7-21-85  
ADC or ADD signature (initials, name, date)  
Thomas W. Selby 7/24/95  
ADD signature (final reviewer) Date

RESTRICTED

CASCADE SERVICES DEPARTMENT

PROCESS LABORATORY

RADIATION GROUP

HEALTH SURVEY REPORT

Date of Issue December 12, 1947

DISTRIBUTION LIST

Mr. E. M. Blacksher  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Mr. W. B. Humes  
Mr. W. S. Jones  
Mr. L. F. Lieber  
Mr. M. S. Lisso  
Mr. D. J. Mahagan  
Mr. J. A. Marshall  
Mr. H. M. Preuss

Mr. M. F. Schwenn  
Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. M. B. Stringfellow  
Mr. S. Visner  
Mr. R. M. Williams  
Mr. L. C. Willson  
Mr. R. A. Winkel  
File

RESTRICTED

RESTRICTED

HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location: K-303-7

Date: December 8, 1947

12-1-47 In the K-1301 conversion room all beta-gamma measurements on the heaters, cold traps, and reactors were zero.

Beta-gamma measurements on the work bench, tool table, and decontamination tanks in the K-1303 decontamination room varied from 0.000 to 0.024 and averaged 0.004 R/8 hours.

12-2-47 All beta-gamma measurements on the cylinders, carbon traps, and withdrawal lines in K-631 were zero.

Beta-gamma measurements on the cylinders in K-131 varied from 0.007 to 0.010 averaging 0.009 R/8 hours.

12-4-47 In K-631 all beta-gamma measurements on the cylinders were zero.

The beta-gamma measurements on the cylinders in K-131 varied from 0.007 to 0.014 and averaged 0.010 R/8 hours.

Beta-gamma measurements on the reactors, cold traps, and heaters in the K-1301 conversion room were all zero.

In the K-1303 decontamination room beta-gamma measurements on the tool table and decontamination tanks varied from 0.000 to 0.024 averaging 0.003 R/8 hours.

12-5-47 Beta-gamma measurements were made on ten (10) welding machines in K-1131, and all were zero.

Air samples of air-borne alpha-active dust were as follow:

K-306-7 P.W. Station, seven feet east of withdrawal manifolds	12-1-47	0.2	Alpha counts/min/ft <sup>3</sup>
	12-2-47	0.1	"
	12-3-47	0.1	"
	12-4-47	2.9	"
	12-5-47	1.2	"
K-1301, inside of weighing room, operators wore respirators	12-1-47	25.6	"

RESTRICTED

RESTRICTED

-2-

			Alpha counts/min/ft <sup>3</sup>
K-1301, inside of transfer room	12-4-47	0.1	"
K-1303, decontamination room,	12-1-47	0.5	"
between tanks A & B	12-4-47	0.4	"
K-1405, center of laboratory	12-1-47	0.2	"
K-1405, center of large room	12-1-47	0.2	"
K-631, near withdrawal manifolds	12-2-47	0.1	"
	12-4-47	0.2	"
K-631, sampling line of drain line			"
#1 being cut, 1' from operation	12-4-47	0.3	"
K-131, near center of room	12-2-47	0.1	"
	12-4-47	0.1	"
K-131, valve being changed on cylinder,			
6 inches from operation	12-3-47		"
Before operation was started		0.1	"
Old valve being removed and			"
new one being installed		0.1	"
After operation was completed		0.2	"
K-131, valve being changed on cylinder, 1'			
from operation	12-4-47		"
Old valve being removed and			"
new one being installed		0.2	"
After operation was completed		0.4	"
K-131, flexible hose in bath C being			"
out, 2 feet from operation	12-4-47	0.2	"
K-131, Beach Russ being removed	12-5-47		"
Oil being drained from pump,			"
1 foot from operation		0.0	"
After exhaust line was broken,			"
6 inches from opening		0.0	"
K-312-3, pump shop, 2 inches above top of			
cylinder of Valley Iron Pump from			
K-312-1 cell 7	12-2-47		"
Before piston was removed		0.0	"
After piston was removed		0.5	"
K-312-2, cold trap room, Beach Russ pump being pulled			
Before pump was opened,			"
1 foot from pump	12-2-47	0.0	"
Intake line being cut,			"
1 foot from operation	12-3-47	0.0	"
End of cylinder chamber being			"
cut off and cylinder being re-			"
moved, 1 foot from operation	12-3-47	0.1	"
After operation was completed	12-3-47	0.0	"
K-1401, seal shop, between north and			"
center tables	12-4-47	0.0	"

RESTRICTED

-5-

K-301-2, cell 3 pump 6A, seal change, 1 foot from operation	12-4-47	0.1	Alpha counts/min/ft <sup>3</sup>
Before operation started		0.2	"
Seal exhaust lines being dis- connected		38.0	"
Old seal being removed and backplate being washed with trichloroethylene, operators wore gas masks		0.5	"
Metal gasket rings being seated and new seal being installed			

Alpha surface measurements were as follow:

K-1301 Conversion Room	12-1-47	Instrument Number 158
Top of cold trap D	59088	Alpha counts/min.
Top of cold trap C	1376	"
Top of cold trap B	1223	"
Top of cold trap A	917	"
Top of heater D	13290	"
Top of heater C	2293	"
Top of heater B	7383	"
Top of heater A	8860	"
Floor under reactor D	5907	"
Floor under reactor C	47254	"
Floor under reactor B	20674	"
Floor under reactor A	5907	"
Floor between cold traps A & B	1834	"
Floor between cold traps B & C	1528	"
Floor between cold traps C & D	1223	"
Floor near East door	0	"
Floor near south door	1070	"
Floor near north door	611	"

K-1303 Decontamination Room	12-1-47	Instrument Number 158
Top of work bench north end	1070	Alpha counts/min.
Top of work bench south end	764	"
Top of work bench center	1223	"
Top of tool table, west end	0	"
Top of tool table, east end	1223	"
Top of tool table,	459	"
Top of tank L, north side	22150	"
Top of tank L, south side	20674	"
Top of tank L, east side	26580	"
Top of tank L, west side	22150	"
Top of tank E, north side	4430	"
Top of tank E, south side	56115	"
Top of tank E, east side	1987	"
Top of tank E, west side	4586	"

K-1303 Decontamination Room (Cont'd.) 12-1-47

Instrument Number 158

		Alpha counts/min.
Top of tank A, north side	11814	"
Top of tank A, south side	11814	"
Top of tank A, east side	14767	"
Top of tank A, west side	8860	"
Floor south of tank A	11814	"
Floor south of tank A	13290	"
Top of tank C, north side	3383	"
Top of tank C, south side	1376	"
Top of tank C, west side	3210	"
Top of tank C, east side	1376	"
Floor south of tank C	3974	"
Floor south of tank W	8860	"
Floor south of tank W	11814	"
Floor south of tank A	11814	"
Floor south of tank A	13290	"
Floor west of tank A	2140	"
Floor north of tank A	8860	"

K-1405 Laboratory 12-1-47

Instrument Number 158

		Alpha counts/min.
Top of west sink table	0	"
Top of west sink table	153	"
Top of west sink table	0	"
Top of south sink table	0	"
Top of south sink table	0	"
Top of south sink table	0	"
Under East hood	0	"
Under east hood	306	"
Under east hood	153	"
Under east hood	306	"
Top of north sink table	306	"
Top of north sink table	153	"
Top of north sink table	0	"
On floor in center of laboratory	306	"
On floor in center of laboratory	153	"
Floor in front of cabinet	5380	"
Floor in front of cabinet	2446	"
Floor in front of cabinet	459	"

K-1405 Large Room 12-1-47

Instrument Number 158

		Alpha counts/min.
On floor near center of room	306	"
On floor near center of room	459	"
On floor near center of room	0	"
On floor near center of room	0	"
On floor near south wall	153	"
On floor near south wall	0	"
Bed of scales	0	"

RESTRICTED

-5-

K-1405 Large Room (Cont'd.)

12-1-47

Instrument Number 158

Top of work bench	0	Alpha counts/min.
Top of work bench	0	"
Top of work bench	153	"
Top of work bench	153	"
Floor near east door	153	"
Floor near north door	0	"
Floor under platform	0	"
Floor under platform	153	"

K-631 Withdrawal Room

12-2-47

Instrument Number 158

On scales #1	153	Alpha counts/min.
On scales #2	153	"
On scales #3	0	"
On floor south end of scales #1	0	"
On floor south end of scales #2	0	"
On floor south end of scales #3	0	"
On floor between scales 1 & 2	0	"
On floor between scales 2 & 3	0	"
Floor under drain line #1	0	"
Floor under drain line #2	153	"
On floor west of scales #1	0	"
On floor east of scales #3	0	"
Top of operator's desk	0	"
Floor front of operator's desk	0	"

K-131 Feed Room

12-2-47

Instrument Number 158

Box on north end of unit D	4280	Alpha counts/min.
Box on north end of unit C	2751	"
Box on north end of unit B	1223	"
Box on north end of unit A	5197	"
Top of unit A	459	"
Top of unit B	459	"
Top of unit C	611	"
Top of unit D	3974	"
On floor between unit A & B	611	"
On floor between unit B & C	611	"
On floor between unit C & D	764	"
Floor under F-1 Carbon Trap	764	"
Floor under F-2 Carbon Trap	611	"
Floor north of unit B	1223	"
Floor north of unit A	1070	"
Bed of scales	1834	"
Floor west end of cylinder rack	764	"
Top of operator's desk	611	"

RESTRICTED

6.



RESTRICTED

-6-

K-1301 Conversion Room

12-4-47

Instrument Number 158

		Alpha counts/min.
Top of cold trap A	1529	"
Top of cold trap B	1223	"
Top of cold trap C	1529	"
Top of cold trap D	59068	"
Top of heater A	5907	"
Top of heater B	5907	"
Top of heater C	3363	"
Top of heater D	13290	"
On floor under reactor A	2751	"
On floor under reactor B	7384	"
On floor under reactor C	22151	"
On floor under reactor D	33964	"
Wipe tests:		
Top of cold trap D	1070	"
Top of heater A	611	"
Top of heater B	764	"
Top of heater D	611	"
On floor under reactor B	306	"
On floor under reactor C	11814	"
On floor under reactor D	7384	"

K-1303 Decontamination Room

12-4-47

Instrument Number 158

		Alpha counts/min.
North side of top of tank A	23627	"
South side of top of tank A	8860	"
West side of top of tank A	10337	"
East side of top of tank A	11814	"
North side of top of tank C	2904	"
South side of top of tank C	2598	"
West side of top of tank C	2751	"
East side of top of tank C	917	"
North side of top of tank E	3974	"
South side of top of tank E	32487	"
West side of top of tank E	7384	"
East side of top of tank E	5503	"
North side of top of tank L	17720	"
South side of top of tank L	22150	"
West side of top of tank L	25104	"
East side of top of tank L	16244	"
West end of tool table	611	"
Center of tool table	611	"
East end of tool table	1528	"
On floor east end of tool table	1223	"

RESTRICTED

7

~~RESTRICTED~~

-7-

K-1303 Decontamination Room (Cont'd.)

12-4-47

Instrument Number 158

North end of work bench	1834
Center of work bench	0
South end of work bench	1528
On floor side of work bench	1223
On floor center of room	1070

Alpha counts/min.

Wipe tests:

North top side of tank A	764
South top side of tank A	306
West top side of tank A	306
East top side of tank A	917
South top side of tank E	1223
West top side of tank E	611
North top side of tank L	611
South top side of tank L	917
West top of side of tank L	917
East top of side of tank L	764

"  
"  
"  
"  
"  
"  
"  
"  
"  
"

K-1401 Seal Shop

12-4-47

Instrument Number 158

Top of center work bench	308
Top of center work bench	153
Top of center work bench	0
Top of center work bench	0
Top of north work bench	0
Top of north work bench	0
Top of north work bench	153
Top of south work bench	0
Top of south work bench	0
Top of south work bench	0
Top of south work bench	0
On seal	0
On seal	8860
On floor west of bench	3057
On floor center of room	0
On floor center of room	0
Bench against east wall	917
Bench against east wall	0
Bench against east wall	0
Bench against east wall	0
Bench against east wall	0

Alpha counts/min.

"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"

K-631 Withdrawal Room

12-4-47

Instrument Number 158

On scales #1	0
On scales #2	0
On scales #3	611

Alpha counts/min.

"  
"

~~RESTRICTED~~

8

-8-

K-631 Withdrawal Room (Cont'd.)

12-4-47

Instrument Number 158

On floor between scales #1 & 2	0	Alpha counts/min.
On floor between scales #2 & 3	0	"
On floor south east corner of room	0	"
On floor north west corner of room	0	"
On floor center of room	0	"
On floor under drain line #1	153	"
On floor under drain line #2	306	"
On operator's desk	306	"

K-131 Feed Room

12-4-47

Instrument Number 158

Box end of unit A	5808	Alpha counts/min.
Box end of unit B	2293	"
Box end of unit C	4280	"
Box end of unit D	4891	"
Top of unit A	764	"
Top of unit B	0	"
Top of unit C	0	"
Top of unit D	917	"
On floor box end of unit A	1223	"
On floor box end of unit B	764	"
On floor box end of unit C	611	"
On floor box end of unit D	1529	"
On floor between unit A & B	0	"
On floor between unit B & C	306	"
On floor between unit C & D	153	"
On floor under carbon trap F-1	306	"
On floor under carbon trap F-2	0	"

K-1131

12-5-47

Instrument Number 158

Welding machine property #148596	0	Alpha counts/min.
Welding machine property #148596	0	"
Welding machine property #148596	0	"
Welding machine property #148596	0	"
Welding machine property #148596	0	"
Welding machine property #148597	0	"
Welding machine property #148597	0	"
Welding machine property #148597	0	"
Welding machine property #148597	0	"
Welding machine property #148597	0	"
Welding machine property #148599	0	"
Welding machine property #148599	0	"
Welding machine property #148599	0	"
Welding machine property #148599	0	"
Welding machine property #148599	0	"

K-1151 (Cont'd.)

12-5-47

Instrument Number 158

		Alpha counts/min.
Welding machine property #112221	0	"
Welding machine property #112221	0	"
Welding machine property #112221	0	"
Welding machine property #112221	0	"
Welding machine property #112221	0	"
Welding machine property #148598	0	"
Welding machine property #148598	0	"
Welding machine property #148598	0	"
Welding machine property #148598	0	"
Welding machine property #112223	0	"
Welding machine property #112223	0	"
Welding machine property #112223	0	"
Welding machine property #112223	0	"
Welding machine property #176530	0	"
Welding machine property #176530	0	"
Welding machine property #176530	0	"
Welding machine property #176530	0	"
Welding machine property #45501	0	"
Welding machine property #45501	0	"
Welding machine property #45501	0	"
Welding machine property #45501	0	"
Welding machine property #112227	0	"
Welding machine property #112227	0	"
Welding machine property #112227	0	"
Welding machine property #112227	0	"
Welding machine property #112217	0	"
Welding machine property #112217	0	"
Welding machine property #112217	0	"
Welding machine property #112217	0	"

K-301-5 Seal Shop

12-5-47

Instrument Number 127

		Alpha counts/min.
Table of steel	0	"
Table of steel	0	"
Table of steel	0	"
Table of steel	0	"
2 Vices	0	"
4 trash cans	0	"
Floor	0	"
Floor	0	"
Floor	0	"
Floor	0	"
Floor	0	"

RESTRICTED

**-10-**

**K-301-5 Seal Shop (Cont'd.)**

**12-5-47**

**Instrument Number 127**

5 pieces of piping  
1 chain hoist  
1 welding table  
2 tool cabinets

0	Alpha counts/min.
0-	"
0	"
0-	"

**K-301-5 Seal Shop**

12-5-47

**Instrument Number 127**

- 2 by 4 in shop (scrap lumber)
- 2 by 4 in shop (scrap lumber)
- 2 cabinets, front and back
- 3 440 volts extension cords
- 8 1 $\frac{1}{2}$ " rubber water hose
- 2 110 volts extension cords
- Bundle of 1/2" copper tubing
- 3 work benches
- 1 bundle of gasket material
- 5 pieces of 6" pipes
- 1 welding stand
- all of floor space
- 1 welder's light shield
- 1 vice
- 1 2" chain
- 1 electric fan
- 1 piece of screen wire
- 4 trash containers
- 3 zinc buckets
- 3 sealed 5 gallon containers
- 1 machine hoist

[illegible]

H. J. Culbert

**H. J. Culbert**

**Approved:**

W. C. Hartman

W. C. Hartman

JHP/nt

RESTRICTED

10

RESTRICTED

CASCADE SERVICES DEPARTMENT  
PROCESS LABORATORY  
RADIATION GROUP

HEALTH SURVIVY REPORT

Date of Issue December 18, 1947

DISTRIBUTION LIST

Mr. E. M. Blacksher  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Mr. W. B. Humes  
Mr. W. S. Jones  
Mr. L. F. Lieber  
Mr. M. S. Lisco  
Mr. D. J. Mahogan  
Mr. J. A. Marshall  
Mr. H. M. Preuss

Mr. M. P. Schwann  
Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. M. B. Stringfellow  
Mr. S. Visner  
Mr. R. M. Williams  
Mr. L. C. Willson  
Mr. R. A. Winkel  
File

RESTRICTED

RESTRICTED

HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location: K-303-7

Date: December 16, 1947

12-8-47 All beta-gamma measurements on the heaters, cold traps, and reactors in the K-1301 conversion room were zero.

In the K-1303 decontamination room beta-gamma measurements on the tool table, work bench, and decontamination tanks varied from 0.000 to 0.117 and averaged 0.007 R/8 hours. The value 0.117 R/8 hours was measured on a spot on the floor at the east end of the tool table; this spot was immediately decontaminated.

12-9-47 Beta-gamma measurements on the cylinders, carbon traps, and #2 withdrawal line in K-631 varied from 0.000 to 0.007 and averaged 0.001 R/8 hours.

In K-131 beta-gamma measurements on the cylinders varied from 0.009 to 0.014 with an average of 0.012 R/8 hours.

12-10-47 In the K-1301 conversion room the beta-gamma measurements on the cold traps, heaters, and reactors were all zero.

Beta-gamma measurements on the tool table and decontamination tanks in the K-1303 decontamination room varied from 0.000 to 0.028 and averaged 0.002 R/8 hours.

12-11-47 In K-631 beta-gamma measurements on the cylinders and carbon traps were all zero.

Beta-gamma measurements on the cylinders in K-131 varied from 0.009 to 0.012 and averaged 0.010 R/8 hours.

Air samples of air-borne alpha-active dusts were as follow:

K-506-7 P.W. Station, seven feet east of withdrawal manifolds	12-8-47	0.0	Alpha counts/min/ft <sup>3</sup>	LG
	12-9-47	22.3	"	
	12-10-47	0.2	"	
K-1301, inside of weighing room	12-8-47	0.0	"	
	12-10-47	0.1	"	
K-1303, decontamination room, between tanks D & E	12-8-47	1.0	"	
	12-10-47	0.0	"	

RESTRICTED

RESTRICTED

-2-

K-1405, center of laboratory	12-8-47	0.0	Alpha counts/min/ft <sup>3</sup>
K-631, near withdrawal manifolds	12-8-47	0.0	"
	12-11-47	0.0	"
K-131, center of room	12-9-47	0.1	"
K-131, south of water fountain	12-11-47	0.0	"
K-303-10, cell 6 pump 4B seal change	12-9-47		
Old seal being removed		1334.0	"
Backplate being washed with trichloroethylene		183.2	"
Metal gasket rings being seated		1.7	"
K-1401, seal shop	12-10-47	0.0	"
K-312-2, cell 21 pump 1 seal change	12-9-47		
Before work was started		0.2	"
While seal being changed		1.7	"
After work was completed		0.2	"
K-1004-C, Requested by Dr. W. W. Boardman	12-11-47		
Room 220, in front of hood		0.0	"
Room 220, west end of room		0.0	"
Room 219, at front of room		0.0	"
Room 219, at rear of room		0.0	"
Room 214, at east end of room		0.0	"
Room 214, at west end of room		0.0	"
Room 206, in front of operator's desk		0.0	"
Room 206, in front of west balance table		0.0	"
K-1004-D, Requested by Mr. H. A. Bernhardt			
Room 17, in front of hood in northeast corner of room	12-11-47	0.0	"
Room 17, back of room	12-11-47	0.0	"
Room 19, southeast corner of room	12-11-47	0.0	"
Room 19, northeast corner of room	12-11-47	0.0	"
Room 21, in front of west hood	12-12-47	0.0	"
Room 21, north end of tube rack table	12-12-47	0.0	"
Room 05, in front of hood	12-12-47	0.0	"
Room 05, in front of hood	12-12-47	0.1	"
K-303-6, cell 6 pump 3B seal change	12-12-47	1239.3	"

RESTRICTED

13



*Cut it out*

K-301-3, cell 3 pump 1B seal change	12-12-47	266.3	Alpha counts/min/ft <sup>3</sup>
Old seal being removed			"
Backplate being washed with trichloroethylene		23.9	"
Metal gasket rings being seated		1.0	"
K-304-4, cell 2 pump 4B seal change	12-14-47	13.0	"
K-304-4, cell 2 pump 5A seal checked	12-14-47	0.6	"
K-304-4, cell 2 pump 2A gasket change	12-14-47	0.9	"

Alpha surface measurements were as follow:

K-1301 Conversion Room	12-8-47	Instrument Number 199
Top of cold trap A	679	Alpha counts/min.
Top of cold trap B	905	"
Top of cold trap C	2490	"
Top of cold trap D	30030	"
Top of heater A	4527	"
Top of heater B	4527	"
Top of heater C	3622	"
Top of heater D	10920	"
On floor under reactor A	2264	"
On floor under reactor B	21840	"
On floor under reactor C	19110	"
On floor under reactor D	16380	"
Wipe tests:		
Top of cold trap D	1811	"
Top of heater D	1584	"
On floor under reactor B	453	"
On floor under reactor C	1811	"
On floor under reactor D	1811	"

K-1303 Decontamination Room	12-8-47	Instrument Number 199
North side of top of tank C	3622	Alpha counts/min.
South side of top of tank C	2264	"
West side of top of tank C	2943	"
East side of top of tank C	1132	"
North side of top of tank D	16380	"
South side of top of tank D	13650	"
West side of top of tank D	13650	"
East side of top of tank D	6338	"
North side of top of tank E	3622	"
South side of top of tank E	21840	"
West side of top of tank E	4074	"
East side of top of tank E	7243	"
North side of top of tank L	16380	"
South side of top of tank L	16380	"
West side of top of tank L	16380	"

-4-

## K-1303 Decontamination Room (Cont'd.)

East side of top of tank L	16380	Alpha counts/min.
West end of tool table	1811	"
Center of tool table	2037	"
East end of tool table	2037	"
On floor east end of tool table	30030	"
North end of work bench	2490	"
Center of work bench	679	"
South end of work bench	2037	"
On floor side of work bench	1584	"
On floor center of room	1358	"
Wipe tests:		
North side of top of tank D	2037	"
South side of top of tank D	226	"
West side of top of tank D	453	"
South side of top of tank E	1358	"
North side of top of tank L	2490	"
South side of top of tank L	4300	"
West side of top of tank L	1584	"
East side of top of tank L	2716	"

## K-1405 Laboratory

12-8-47

Instrument Number 199

Top of south sink table	0	Alpha counts/min.
Top of south sink table	0	"
Top of south sink table	0	"
Top of west sink table	0	"
Top of west sink table	0	"
Top of west sink table	0	"
Under hood, east wall	226	"
Under hood, east wall	1584	"
Under hood, east wall	0	"
Under hood, east wall	0	"
Under hood, east wall	0	"
Top of north sink table	0	"
Top of north sink table	0	"
Top of north sink table	0	"
On floor	0	"
On floor	0	"
On floor	0	"
On floor	0	"

## K-1405 Large Room

12-8-47

Instrument Number 199

On floor along west wall	0	Alpha counts/min.
On floor along west wall	0	"
On floor along west wall	0	"
On floor along west wall	0	"

K-1405 Large Room (Cont'd.)

		Alpha counts/min.
On floor along south wall	0	"
On floor along south wall	0	"
On floor along south wall	0	"
On bed of scales	0	"
On floor around water tanks	0	"
On floor around water tanks	0	"
On floor around water tanks	0	"
On floor near center of room	453	"
On floor near center of room	679	"
On floor near center of room	0	"
On floor near center of room	0	"
On floor near north door	0	"
On floor near north door	0	"
Top of work bench	0	"
Top of work bench	0	"
Top of work bench	0	"

K-631 Withdrawal Room

12-9-47

Instrument Number 199

		Alpha counts/min.
On bed of scales #1	453	"
On bed of scales #2	453	"
On bed of scales #2	226	"
On floor between scales 1 & 2	0	"
On floor between scales 2 & 3	0	"
On floor south end of scales #1	0	"
On floor south end of scales #2	0	"
On floor south end of scales #3	226	"
On floor under drain line #1	226	"
On floor under drain line #2	453	"
On floor north end of scales #1	0	"
On floor north end of scales #2	0	"
On floor north end of scales #3	0	"
Top of operator's desk	0	"

K-131 Feed Room

12-9-47

Instrument Number 199

		Alpha counts/min.
Box on north end of unit A	3169	"
Box on north end of unit B	1584	"
Box on north end of unit C	2264	"
Box on north end of unit D	6338	"
On floor between unit A & B	679	"
On floor between unit B & C	453	"
On floor between unit C & D	453	"
Top of unit C, north end	226	"
Top of unit C, south end	0	"
On floor north end of unit A	453	"
On floor north end of unit B	453	"
On floor north end of unit C	679	"

-6-

K-131 Feed Room (Cont'd.)

On floor north end of unit D	905
Bed of scales	1358
Top of operator's desk	226
Floor west end of cylinder rack	0
Floor under carbon trap #1099	226
Floor under carbon trap #1098	226
Floor under carbon trap #1098	453

Alpha counts/min

"  
"  
"  
"  
"  
"

K-1301 Conversion Room

12-10-47

Instrument Number 199

Top of cold trap A	2264
Top of cold trap B	1584
Top of cold trap C	2490
Top of cold trap D	32760
On floor under reactor A	5885
On floor under reactor B	5432
On floor under reactor C	7696
On floor under reactor D	7696
Top of heater A	5885
Top of heater B	13650
Top of heater C	3395
Top of heater D	16380
On floor between reactor A & B	1811
On floor between reactor B & C	1358
On floor between reactor C & D	1358
Floor near east door	1137
Floor near south door	1132
Floor near north door	905

Alpha counts/min.

"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"

K-1303 Decontamination Room

12-10-47

Instrument Number 199

Top of work table	1584
Top of work table	1358
Top of work table	905
Top of work table	453
Top of tool bench	2490
Top of tool bench	1811
Top of tool bench	1132
Top of tool bench	1358
Floor front of work table	3622
Floor front of work table	1811
Floor front of telephone	905
Floor under vice	103740
Floor under vice	13650
Floor front of tool bench	3169
Floor front of tool bench	2264
Floor end of work bench	1132
Top of tank L	13650
Top of tank L	16380
Top of tank L	21840

Alpha counts/min.

"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"

RESTRICTED

-7-

K-1303 Decontamination Room (Cont'd.)

		Alpha counts/min.
Top of tank E	4527	"
Top of tank E	3395	"
Top of tank E	7243	"
Top of tank E	6790	"
Top of tank D	16380	"
Top of tank D	13650	"
Top of tank D	10920	"
Top of tank D	8600	"
Floor side of tank L	2490	"
Floor side of tank L	1811	"
Floor side of tank L	1811	"
Floor side of tank D	4527	"
Floor side of tank D	7922	"
Floor side of tank D	10920	"
Floor side of water tank	3169	"
Top of tank C	2264	"
Top of tank C	2490	"
Top of tank C	3169	"
Top of tank C	2264	"
Floor side of tank C	1132	"

K-1401 Seal Shop

12-10-47

Instrument Number 199

		Alpha counts/min.
Top of north work bench	226	"
Top of north work bench	226'	"
Top of north work bench	0	"
Top of north work bench	0'	"
Top of south work bench	0	"
Top of south work bench	0	"
Top of south work bench	0	"
Top of center work bench	0'	"
Top of center work bench	0	"
Top of center work bench	0'	"
Top of center work bench	0	"
On seals	1811	"
On seals	1584'	"
On seals	905	"
On seals	1358'	"
On seals	0	"
On seals	1358'	"
On seals	1811	"
On seals	0'	"
On seals	0	"

RESTRICTED

-8-

K-131 Feed Room

12-11-47

Instrument Number 199

Box end of unit A	7017
Box end of unit B	3622
Box end of unit C	3169
Box end of unit D	4753
Top of unit A	4980
Top of unit B	0
Top of unit C	0
Top of unit D	905
On floor box end of unit A	679
On floor box end of unit B	905
On floor box end of unit C	1132
On floor box end of unit D	2037
On floor between unit A & B	226
On floor between unit B & C	453
On floor between unit C & D	453
On floor under carbon trap F-1	226
On floor under carbon trap F-2	226

Alpha counts/min.

"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"  
"

K-631 Withdrawal Room

12-11-47

Instrument Number 199

On scales #1	0
On scales #2	0
On scales #3	453
On floor between scales #1 & #2	0
On floor between scales #2 & #3	0
On floor under drain line #1	0
On floor under drain line #2	226
On floor south east corner of room	0
On floor north west corner of room	0
On floor center of room	0

Alpha counts/min.

"  
"  
"  
"  
"  
"  
"  
"  
"  
"

K-631 Carbon Trap Room

12-11-47

Instrument Number 199

On floor between large traps	0
On floor under seal exhaust trap	226
On floor side of trap #T-207	0
On floor side of trap #T-212	0
On floor side of trap #T-210	0
On scales	453

Alpha counts/min.

"  
"  
"  
"  
"

K-1004-C, Room 220

12-11-47

Instrument Number 199

Under hood, south wall	0
Under hood, south wall	0
Under hood, south wall	0
Under hood, south wall	0
Top of work bench, east wall	0
Top of work bench, east wall	0
Top of work bench, east wall	0

Alpha counts/min.

"  
"  
"  
"  
"  
"  
"

RESTRICTED

-9-

K-1004-C, Room 220 (Cont'd.)

Top of work bench, north wall  
Top of work bench, north wall  
Top of work bench, north wall  
Top of table center of room  
Top of table center of room  
Top of table center of room  
Around on Mercury Stand  
Around on Mercury Stand  
Around on Mercury Stand  
On floor  
On floor  
On floor  
On floor

0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0

Alpha counts/min.

n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n

K-1004-C, Room 219

12-11-47

Instrument Number 199

On floor  
On floor  
On floor  
On floor  
On floor  
On top edge of sink  
On top edge of sink  
On top edge of sink  
On top edge of sink  
On table against south wall  
On table against south wall  
On table against south wall  
On table against south wall  
Top of operator's desk  
Top of operator's desk  
Top of operator's desk  
On east panel board  
On east panel board  
On west panel board  
On west panel board

0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0  
0

Alpha counts/min.

n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n

K-1004-C, Room 214

12-11-47

Instrument Number 199

Top of table, north wall  
Top of table, north wall  
Top of table, north wall  
Small table, north east corner of room  
Small table, north east corner of room  
Small table, north east corner of room  
Edge of sink north east corner of room  
Edge of sink north east corner of room  
Top of vice table  
Top of vice table

0  
0  
0  
226  
226  
0  
0  
0  
0  
0  
0

Alpha counts/min.

n  
n  
n  
n  
n  
n  
n  
n  
n  
n  
n

RESTRICTED

20

RESTRICTED

-10-

K-1004-C, Room 214 (Cont'd.)

Top of table, south wall	0	Alpha counts/min.
Top of table, south wall	0	"
On floor near north east corner	3622	"
On floor near north east corner	1358	"
On floor near north east corner	0	"
On floor front of sink	0	"
On floor front of sink	0	"
On floor near south wall	0	"
On floor near south wall	0	"
On floor near south wall	0	"

K-1004-C, Room 206

12-11-47

Instrument Number 199

Top of south wall balance table	0	Alpha counts/min.
Top of south wall balance table	0	"
Top of south wall balance table	0	"
Front of cabinet, south wall	0	"
Front of cabinet, south wall	0	"
Front of cabinet, south wall	0	"
On table against north wall	0	"
On table against north wall	0	"
On table against west wall	0	"
On table against west wall	0	"
Top of operator's desk	0	"
Operator's chair	0	"
On floor	0	"
On floor	0	"
On floor	0	"
On floor	0	"
On floor	0	"

K-1004-D, Room 17

12-11-47

Instrument Number 199

Inside hood, north west corner of room	0	Alpha counts/min.
Inside hood, north west corner of room	0	"
Inside hood, north west corner of room	0	"
Top of bench, against west wall	0	"
Top of bench, against west wall	0	"
Top of bench, against west wall	0	"
Top of bench, against west wall	0	"
Top of bench, against west wall	0	"
Top of table, front of room	226	"
Top of table, front of room	226	"
Top of table, front of room	0	"
On floor along west wall	0	"
On floor along west wall	0	"
On floor along west wall	0	"
On floor front of cabinets	0	"

RESTRICTED



-11-

K-1004-D, Room 17 (Cont'd.)

On floor front of cabinets	0	Alpha counts/mir.
On floor front of cabinets	0	"
On floor near center of room	0	"
On floor near center of room	0	"
On floor near center of room	0	"

K-1004-D, Room 19

12-11-47

Instrument Number 199

Under hood, north east corner of room	679	Alpha counts/min.
Under hood, north east corner of room	453	"
Under hood, north east corner of room	0	"
Under hood, north east corner of room	226	"
Top of spectrograph table	0	"
Top of spectrograph table	0	"
Top of spectrograph table	0	"
Top of spectrograph table	0	"
Top of spectrograph table	0	"
Top of sink bench	0	"
Top of sink bench	0	"
Top of sink bench	0	"
Top of sink bench	0	"
Top of south table	0	"
Top of south table	0	"
Top of south table	0	"
Top of balance table	0	"
Top of balance table	0	"
Top of balance table	0	"
East end of spectrograph table	3622	"
East end of spectrograph table	4980	"

K-1004-D, Room 21

12-12-47

Instrument Number 199

Under west hood	0	Alpha counts/min.
Under west hood	0	"
On table top, south of hood	226	"
On table top, south of hood	0	"
On table top, south of hood	0	"
On floor west of hood	0	"
On floor west of hood	0	"
Bottom of operator's shoes	0	"
Top of tube rack table	0	"
Top of tube rack table	0	"
Top of tube rack table	0	"
Top of bench against east wall	0	"
Top of bench against east wall	0	"
Top of bench against east wall	0	"
Top of bench against east wall	0	"
Inside of east hood	0	"
Inside of east hood	0	"
Inside of east hood	0	"

RESTRICTED

-12-

K-1004-D, Room 05

12-12-47

Instrument Number 199

Top of vice table	0	Alpha counts/min.
Top of vice table	0	"
Top of vice table	0	"
On floor around vice table	0	"
On floor around vice table	0	"
On floor around vice table	0	"
Inside hood	0	"
Inside hood	0	"
Inside hood	0	"
Top of tube rack stand	0	"
Top of tube rack stand	0	"
Top of tube rack stand	0	"

K-301-3 Seal Change - Cell 3 pump 1B

12-12-47

Instrument Number 199

On old seal	1584	Alpha counts/min.
On old seal	905	"
Right rubber glove	7017	"
Left rubber glove	7243	"
Mechanic's leather gloves	0	"
Mechanic's leather gloves	0	"
Rubber gloves	0	"
Tools that were used	0	"
Tools that were used	0	"
Tools that were used	0	"
Tools that were used	0	"
Load Rocker (Bearing)	0	"
Load Rocker (Bearing)	0	"
Load Rocker (Bearing)	0	"
Load Rocker (Bearing)	0	"
On floor around pump	0	"
On floor around pump	0	"
On floor around pump	0	"
On floor around pump	0	"
On floor around pump	0	"

H. J. Culbert

H. J. Culbert

Approved: W. C. Hartman

W. C. Hartman

JHP/nf

RESTRICTED

23

RESTRICTED

CASCADE SERVICES DEPARTMENT

PROCESS LABORATORY

RADIATION SURVEY

HEALTH SURVEY REPORT

Date of Issue December 2, 1947

DISTRIBUTION LIST

Mr. W. C. Hartman  
Mr. A. P. Huber  
Mr. W. B. Humes  
Mr. M. S. Liso  
Mr. J. A. Marshall  
Mr. H. M. Preuss  
Mr. M. F. Schwenn

Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. S. Visner  
Mr. L. C. Willson  
Mr. R. A. Winkel  
File

RESTRICTED

RESTRICTED

HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location K-303-7

Date: December 2, 1947

11-24-47 In the K-1303 decontamination room beta-gamma determinations on the work bench, tool table and decontamination tanks varied from 0.000 to 0.014 and averaged 0.002 R/8 hours.

All beta-gamma determinations on the heaters, reactors, and cold traps in the K-1301 conversion room were zero.

Beta-gamma determinations on the carbon traps and vaporizers were all zero in K-131, and the determinations on the cylinders varied from 0.007 to 0.012 with an average of 0.010 R/8 hours.

All beta-gamma determinations on the cylinders in K-631 were zero.

11-25-47 In the K-1301 conversion room the beta-gamma determinations on the reactors, heaters and cold traps were all zero.

Beta-gamma determinations on the work bench, tool table, and decontamination tanks in the K-1303 decontamination room varied from 0.000 to 0.017 averaging 0.003 R/8 hours.

Air samples of air-borne alpha-active dust were as follow:

K-303-7 P.W. Station, seven feet	11-24-47	0.1	Alpha counts/min/ft <sup>3</sup>
east of withdrawal manifolds	11-25-47	0.1	"
	11-26-47	0.2	"
	11-27-47	0.1	"
	11-28-47	0.4	"
K-631 near withdrawal manifolds	11-25-47	0.0	"
K-131 near center of room	11-25-47	0.2	"
K-1301 inside of transfer room	11-25-47	0.1	"
K-1301 inside of weighing room	11-26-47	0.0	"

RESTRICTED

25

~~RESTRICTED~~

-2-

K-1303 decontamination room  
between tanks A & E

K-1401 seal shop

K-1405 center of large room

K-1405 center of laboratory

11-26-47 0.0 Alpha counts/min/ft<sup>3</sup>  
11-26-47 0.1 "

11-26-47 0.0 "

11-26-47 0.0 "

11-26-47 3.2 ——— G.S. ?

H. J. Culbert

H. J. Culbert

Approved:

W. C. Hartman

W. C. Hartman

JHP/nf

~~RESTRICTED~~

26

R E S T R I C T E D

CASCADE SERVICES DEPARTMENT

PROCESS LABORATORY

RADIATION SURVEY

HEALTH SURVEY REPORT

Date of Issue November 24, 1947

DISTRIBUTION LIST

Mr. S. C. Barnett  
Dr. C. K. Beck  
Dr. M. J. Costello  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Mr. W. B. Humes  
Mr. M. S. Lisso  
Mr. J. A. Marshall  
Mr. H. H. Preuss

Mr. M. F. Schwenn  
Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. S. Visner  
Mr. L. C. Willson  
Mr. R. A. Winkel  
Mr. J. C. Worthington  
File

R E S T R I C T E D

~~RESTRICTED~~

# HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location: K-303-7

Date: November 24, 1947

11-17-47 In the K-1301 conversion room beta-gamma measurements on the cold traps, reactors, and heaters were all zero.

In the K-1303 decontamination room beta-gamma measurements on the work bench, tool table, and decontamination tanks varied from 0.000 to 0.010 and average 0.002 R/8 hours.

11-18-47 In K-131 beta-gamma measurements on the carbon traps were zero, and those on the cylinders varied from 0.007 to 0.012 with an average of 0.010 R/8 hours.

In K-631 beta-gamma measurements on the cylinders and carbon traps were all zero.

11-19-47 Beta-gamma measurements on the work bench, tool table, and decontamination tanks in the K-1303 decontamination room varied from 0.000 to 0.014 with an average of 0.003 R/8 hours.

Beta-gamma measurements on the cold traps, heaters and reactors in the K-1301 conversion room were all zero.

11-20-47 All beta-gamma measurements on the cylinders and carbon traps in K-631 were zero.

The beta-gamma measurements on the cylinders in K-131 varied from 0.007 to 0.014 averaging 0.010 R/8 hours.

Air samples of air-borne alpha-active dusts were as follow:

K-306-7 P.W. Station, seven feet east of withdrawal manifolds	11-17-47	0.1	Alpha counts/min/ft <sup>3</sup>	CG?
	11-18-47	6.2	"	
	11-19-47	0.3	"	
	11-20-47	0.1	"	
	11-21-47	0.1	"	
K-1301, inside of weighing room door	11-17-47	0.0	"	
	11-19-47	0.2	"	
	11-20-47	0.0	"	
K-1303, Decontamination room between tanks A & E	11-17-47	0.1	"	
	11-19-47	0.1	"	
	11-20-47	0.0	"	
K-1405, center of laboratory	11-17-47	0.1	"	
K-631, near withdrawal manifolds	11-18-47	0.0	"	

28  
~~RESTRICTED~~

K-131, near center of room	11-18-47	0.0	Alpha counts/min/ft <sup>3</sup>
K-1401, between tables in seal shop	11-19-47	0.0	"
K-1024, Line recorder manifold being partly dismantled, 8 inches from operation Requested by Mr. R. Millican	11-20-47		
Before any joints were out		0.1	"
Joint #4 being out		0.0	"
Joint #13 being out		3.1	"
Joint #55 being out		0.0	"
After all joints were out		0.2	"
K-1401, seal shop, during 30 minute process of melting solder from seal, 1 foot from operation Requested by Mr. J. Flynn	11-17-47		
During first 10 minutes of process		0.1	Alpha counts/min/ft <sup>3</sup>
During second 10 minutes of process		0.0	"
During last 5 minutes of process		0.2	"
While seal was being buffed with a steel wire wheel		5.4	" - 65?

H. J. Culbert

H. J. Culbert

Approved:

W. C. Hartman

W. C. Hartman

HJC/vw

R-E-S-T-R-I-C-T-E-D



RESTRICTED

CASCADE SERVICES DEPARTMENT

PROCESS LABORATORY

RADIATION SURVEY

HEALTH SURVEY REPORT

Date of Issue November 19, 1947

DISTRIBUTION LIST

Mr. L. G. Bamer  
Mr. S. C. Barnett  
Dr. C. K. Beck  
Dr. H. J. Costello  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Mr. W. B. Humes  
Mr. M. S. Lisso  
Mr. J. A. Marshall

Mr. H. M. Preuss  
Mr. M. F. Schwenn  
Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. S. Visner ✓  
Mr. L. C. Willson  
Mr. R. A. Winkel  
File

RESTRICTED

RESTRICTED

HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location: K-303-7

Date: November 19, 1947

11-10-47 Beta-gamma determinations on the heaters, reactors, and cold traps in the K-1301 conversion room were all zero.

Beta-gamma determinations on the work bench, tool table, and decontamination tanks in the K-1303 decontamination room varied from 0.000 to 0.016 and averaged 0.003 R/8 hours.

11-11-47 All beta-gamma determinations on the cylinders and carbon traps in K-631 were zero.

In K-131 beta-gamma determinations on the cylinders varied from 0.012 to 0.017 with an average of 0.014 R/8 hours.

11-12-47 All beta-gamma determinations on the reactors, heaters, and cold traps in the K-1301 conversion room were zero.

In the K-1303 decontamination room beta-gamma determinations on the work bench, tool table, and decontamination tanks varied from 0.000 to 0.028 with an average of 0.006 R/8 hours.

11-13-47 Beta-gamma determinations on the cylinders and carbon traps in K-631 were all zero.

Beta-gamma determinations on the cylinders in K-131 varied from 0.010 to 0.017 and averaged 0.013 R/8 hours.

Air samples of air-borne alpha-active dusts were as follow:

K-306-7 P.W. Station, seven feet east of withdrawal manifolds	11-10-47	0.5	Alpha counts/min/ft <sup>3</sup>
	11-11-47	0.6	"
	11-12-47	0.2	"
	11-13-47	0.9	"
	11-14-47	0.1	"
K-1301, conversion room between reactors C & D	11-10-47	0.1	"
K-1301, inside of weighing room door	11-12-47	2.3	"
K-1303, decontamination room, between tanks A & E	11-10-47	0.2	"
	11-12-47	1.6	"

31  
RESTRICTED

RESTRICTED

-2-

K-1405, center of downstairs room	11-10-47	0.1	Alpha counts/min/ft <sup>3</sup>
K-1405, center of laboratory	11-10-47	0.0	"
K-1401, seal shop, between tables	11-12-47	0.0	"
K-631, near withdrawal manifolds	11-11-47	0.0	"
	11-13-47	0.0	"
K-131, between baths A & B	11-11-47	0.1	"
	11-13-47	0.0	"

H. J. Culbert

H. J. Culbert

Approved: W. C. Hartman

W. C. Hartman

HJC/nf

RESTRICTED

32

Classy

RESTRICTED

CASCADE SERVICES DEPARTMENT

PROCESS LABORATORY

RADIATION SURVEY

HEALTH SURVEY REPORT

Date of Issue November 12, 1947

DISTRIBUTION LIST

Mr. L. G. Bamer  
Mr. S. C. Barnett  
Dr. C. K. Beck  
Dr. M. J. Costello  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Mr. W. B. Humes  
Mr. M. S. Lisso  
Mr. J. A. Marshall

Mr. H. M. Preuss  
Mr. M. P. Schwenn  
Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. S. Visner  
Mr. L. C. Willson  
Mr. R. A. Winkel  
File

RESTRICTED

RESTRICTED

HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location: K-303-7

Date: November 11, 1947

11-3-47 In the K-1301 conversion room beta-gamma measurements on the cold traps, heaters, and reactors were all zero.

In the K-1303 decontamination room beta-gamma measurements on the tool table and decontamination tanks varied from 0.000 to 0.010 and averaged 0.002 R/8 hours.

11-4-47 Beta-gamma measurements on the cylinders and carbon traps in K-631 were all zero.

Beta-gamma measurements on the cylinders in K-131 varied from 0.007 to 0.021 with an average of 0.015 R/8 hours.

11-5-47 Beta-gamma measurements on the cold traps, heaters, and reactors in the K-1301 conversion room were all zero.

In the K-1303 decontamination room beta-gamma measurements on the work bench, tool table, and decontamination tanks varied from 0.000 to 0.010 and averaged 0.002 R/8 hours.

Air samples of air-borne alpha-active dust were as follows:

K-306-7 P.W. Station, seven feet east of withdrawal manifolds	11-3-47	0.1	Alpha counts/min/ft <sup>3</sup>
	11-4-47	0.0	"
	11-5-47	0.2	"
	11-6-47	0.1	"
	11-7-47	0.2	"
K-1301 outside of weighing room door	11-3-47	0.0	"
K-1301 conversion room between reactors B & C	11-5-47	0.5	"
K-1303 decontamination room, between tanks A & B	11-3-47	0.0	"
	11-5-47	13.9	"
K-1405 laboratory	11-3-47	0.1	"
K-1405 downstairs room	11-3-47	0.0	"
K-1401 seal shop	11-5-47	0.2	"
K-631 near withdrawal manifolds	11-4-47	0.1	"
K-131 six feet from water fountain	11-4-47	0.1	"

RESTRICTED

K-1004-D

11-3-47

Requested by Mr. H. A. Bernhardt

	Alpha counts/min/ft <sup>3</sup>	
Room 17, northwest corner of room	0.0	"
Room 17, northeast corner of room	0.0	"
Room 19, at front of hood in northeast corner of room	0.1	"
Room 19, near furnace in northwest corner of room	0.1	"
Room 21, at north end of vacuum bench	0.1	"
Room 21, at front of hood	0.0	"
Room 05, at front of hood	0.0	"
Room 05, near windows	0.1	"

K-1004-C

11-4-47

Requested by Dr. W. W. Boardman

Room 220, at front of hood	0.0	"
Room 220, at front of furnace in southeast corner of room	0.0	"
Room 219, between spectrometers U & T	0.0	"
Room 219, south side of room	0.0	"
Room 214, in front of conversion system	0.0	"
Room 214, in northeast corner of room	0.1	"
Room 206, center of room	0.1	"

K-310-3 Cell Floor

10-23-47

Beside cell 7 pump 1B	0.0	"
Beside cell 4 pump 4B	0.0	"

K-310-2 Cell Floor

10-23-47

Beside cell 1 pump 5B	0.0	"
Beside cell 8 pump 5A	0.0	"

K-310-1 Cell Floor

10-23-47

Beside cell 5 pump 2A	0.1	"
Beside cell 4 pump 4B	0.0	"

K-309-3 Cell Floor

10-23-47

Beside cell 5 pump 2A	0.0	"
Beside cell 4 pump 5A	0.1	"

K-309-2 Cell Floor

10-24-47

Beside cell 2 pump 6B	0.0	"
Beside cell 5 pump 5A	0.0	"

~~RESTRICTED~~

-3-

K-309-1 Cell Floor

10-24-47

Beside cell 3 pump 5B  
Beside cell 2 pump 5A

0.0 Alpha counts/min/ft<sup>3</sup>  
0.0 "

K-301-1 Cell Floor

10-24-47

Beside cell 4 pump 6B  
Beside cell 3 pump 2B

0.0 "  
0.0 "

K-301-2 Cell Floor

10-24-47

Beside cell 7 pump 2A  
Beside cell 4 pump 4B

0.0 "  
0.0 "

K-301-3 Cell Floor

10-24-47

Beside cell 6 pump 6A  
Beside cell 7 pump 5A

0.0 "  
0.0 "

K-301-4 Cell Floor

10-24-47

Beside cell 5 pump 3B  
Beside cell 2 pump 6B

0.0 "  
0.0 "

K-301-5 Cell Floor

10-24-47

Beside cell 1 pump 4B  
Beside cell 6 pump 6A

0.0 "  
0.0 "

K-302-1 Cell Floor

10-24-47

Beside cell 8 pump 2B  
Beside cell 3 pump 1B

0.0 "  
0.0 "

K-302-2 Cell Floor

10-24-47

Beside cell 1 pump 6A  
Beside cell 10 pump 6B

0.0 "  
0.0 "

K-302-3 Cell Floor

10-23-47

Beside cell 2 pump 5A  
Beside cell 4 pump 5A

0.0 "  
0.1 "

K-302-5 Cell Floor

10-23-47

Beside cell 10 pump 6A  
Beside cell 1 pump 2A

0.0 "  
0.0 "

~~RESTRICTED~~

RESTRICTED

-4-

K-303-1 Cell Floor	10-23-47		
Beside cell 2 pump 5A		0.1	Alpha counts/min/ft <sup>3</sup>
Beside cell 8 pump 5A		0.0	"
K-303-2 Cell Floor	10-23-47		
Beside cell 8 pump 2A		0.0	"
Beside cell 2 pump 2A		0.1	"
K-303-3 Cell Floor-	10-23-47		
Beside cell 1 pump 5A		0.0	"
Beside cell 7 pump 5A		0.0	"
K-303-4 Cell Floor	10-23-47		
Beside cell 2 pump 2A		0.0	"
Beside cell 8 pump 5B		0.1	"
K-303-5 Cell Floor	10-23-47		
Beside cell 10 pump 6A		0.1	"
Beside cell 1 pump 1B		0.1	"
K-303-6 Cell Floor	10-23-47		
Beside cell 2 pump 5A		0.1	"
Beside cell 5 pump 2A		0.1	"
K-303-7 Cell Floor	10-23-47		
Beside cell 2 pump 6B		0.1	"
Beside cell 6 pump 4B		0.0	"
K-303-8 Cell Floor	10-23-47		
Beside cell 2 between pumps 5B & 6A		0.1	"
Beside cell 8 pump 5A		0.2	"
K-303-10 Pipe Gallery	10-23-47		
Beside B inlet valve cell 4		0.1	"
Beside B outlet valve cell 7		0.0	"
K-303-9 Pipe Gallery	10-23-47		
Beside B bypass valve cell 8		0.0	"
Beside B inlet valve cell 1		0.1	"

RESTRICTED

37



RESTRICTED

-6-

K-303-8 Pipe Gallery	10-23-47		
Beside B inlet valve cell 4		0.0	Alpha counts/min/ft <sup>3</sup>
Beside B outlet valve cell 7		0.0	"
K-303-7 Pipe Gallery	10-24-47		
Top of housing at A bypass valve cell 1		0.0	"
On catwalk at B inlet valve cell 8		0.0	"
K-303-6 Pipe Gallery	10-24-47		
On catwalk at A inlet valve cell 10		0.1	"
Top of housing at B inlet valve cell 3		0.0	"
K-303-5 Pipe Gallery	10-24-47		
On catwalk at A outlet valve cell 4		0.0	"
Top of housing at B inlet valve cell 7		0.0	"
K-303-4 Pipe Gallery	10-27-47		
Top of housing at B outlet valve cell 4		0.0	"
On catwalk at B bypass valve cell 9		0.1	"
K-303-3 Pipe Gallery	10-27-47		
Top of housing at A outlet valve cell 9		0.1	"
On catwalk at B inverse recycle valve cell 1		0.0	"
K-303-2 Pipe Gallery			
In service gallery at stair door		0.0	"
Top of housing at A inlet valve cell 5		0.0	"
K-303-1 Pipe Gallery	10-27-47		
On catwalk at B inlet valve cell 8		0.0	"
Top of housing at A inlet valve cell 3		0.0	"
K-302-5 Pipe Gallery	10-27-47		
Beside B outlet valve cell 9		0.0	"
On catwalk over maintenance shop		0.0	"

RESTRICTED

R E S T R I C T E D

-6-

K-302-3 Pipe Gallery	10-24-47		
Beside B inlet valve cell 1		0.1	Alpha counts/min/ft <sup>3</sup>
Beside B inlet valve cell 7		0.1	"
K-302-2 Pipe Gallery	10-27-47		
Top of housing at A inverse recycle valve cell 1		0.0	"
On catwalk at A outlet valve cell 5		0.1	"
K-302-1 Pipe Gallery	10-27-47		
On catwalk at cell 7 & 8 coolant pump pit door		0.0	"
Top of housing at B outlet valve cell 4		0.0	"
K-301-5 Pipe Gallery	10-27-47		
Top of housing at A inlet valve cell 3		0.0	"
On catwalk at C-216 evacuation valve cell 5		0.0	"
K-301-4 Pipe Gallery	10-27-47		
On catwalk at B inverse recycle valve cell 7		0.0	"
Top of housing at B inlet valve cell 2		0.0	"
K-301-3 Pipe Gallery	10-27-47		
Service gallery at stair door		0.0	"
Top of housing at A inlet valve cell 5		0.0	"
K-301-2 Pipe Gallery	10-27-47		
On catwalk at A outlet valve cell 8		0.0	"
Top of housing at A bypass valve cell 1		0.0	"
K-301-1 Pipe Gallery	10-27-47		
Top of housing at A inlet valve cell 3		0.0	"
On catwalk at C-216 evacuation valve cell 7		0.1	"
K-309-1 Pipe Gallery	10-27-47		
Top of housing at B inverse recycle valve cell 5		0.0	"
On catwalk at B inlet valve cell 1		0.0	"
K-309-2 Pipe Gallery	10-27-47		
Top of housing at A outlet valve cell 6		0.0	"
Beside A inlet valve cell 1		0.0	"

R E S T R I C T E D

-7-

K-509-3 Pipe Gallery	10-28-47		
On catwalk over maintenance shop		0.0	Alpha counts/min/ft3
Top of housing at B bypass valve cell 5		0.0	"
K-510-1 Pipe Gallery	10-28-47		
On catwalk at A inlet valve cell 6		0.0	"
Top of housing at A outlet valve cell 1		0.0	"
K-510-2 Pipe Gallery	10-28-47		
Top of housing at A inlet valve cell 2		0.0	"
On catwalk at B inverse recycle valve cell 7		0.0	"
K-510-3 Pipe Gallery	10-28-47		
Top of housing at B bypass valve cell 6		0.0	"
On catwalk at B outlet valve cell 1		0.0	"
K-511-1 Pipe Gallery	10-28-47		
On catwalk at C-216 evacuation valve cell 2		0.0	"
Top of housing at A outlet valve cell 10		0.0	"
K-402-1 Operating Floor	10-28-47		
Above B normal building inlet valve		0.0	"
Inside of line recorder station between tube racks A & B		0.0	"
At stair side of cells 7 & 8 coolant pumps		0.0	"
K-402-2 Operating Floor	10-28-47		
Above B inlet valve cell 10		0.0	"
Inside of line recorder station at manifold rough pump		0.0	"
Above A outlet valve cell 2		0.0	"
K-402-3 Operating Floor	10-28-47		
Above A spare building bypass valve		0.0	"
Inside of line recorder station at tube rack A		0.1	"
At Kinney pump SV-3		0.1	"
K-402-4 Operating Floor	10-28-47		
At cell 9 coolant pump		0.0	"
Inside of line recorder station at sample manifold		0.0	"
Above B outlet valve cell 1		0.0	"

K-402-5 Operating Floor	10-28-47		
At cells 1 & 2 coolant pumps		0.0	Alpha counts/min/ft <sup>3</sup>
Inside of line recorder station at sample manifold pump		0.0	"
At carbon trap S-2		0.0	"
K-402-6 Operating Floor	10-29-47		
Above B inlet valve cell 2		0.0	"
Inside of line recorder station at tube rack A		0.1	"
K-402-7 Operating Floor	10-29-47		
Above B bypass valve cell 7		0.1	"
Inside of line recorder station at manifold rough pump		0.1	"
At cells 1 & 2 coolant pumps		0.1	"
K-402-8 Operating Floor	10-29-47		
Above A & B building inverse recycle valves		0.0	"
Inside of line recorder station at sample manifold		0.0	"
At Kinney pump SV-3		0.0	"
K-402-9 Operating Floor	10-29-47		
At cells 9 & 10 coolant pumps		0.0	"
Inside of line recorder station between tube racks A & B		0.1	"
Above A normal building outlet valve		0.1	"
K-402-1 Cell Floor	10-30-47		
Beside cell 1 between pumps 4A & 5B		0.1	"
Beside cell 10 pump 5A		0.1	"
K-402-2 Cell Floor	10-30-47		
Beside cell 4 pump 6B		0.0	"
Beside cell 7 between pumps 2A & 3B		0.1	"
K-402-3 Cell Floor	10-29-47		
Beside cell 9 between pumps 2A & 3B		0.0	"
Beside cell 5 pump 1A		0.0	"
K-402-4 Cell Floor	10-29-47		
Beside cell 2 pump 2A		0.0	"
Beside cell 8 between pumps 4B & 5A		0.0	"

RESTRICTED

-9-

K-402-6 Cell Floor	10-29-47		
Beside cell 10 pump 5B		0.1	Alpha counts/min/ft <sup>3</sup>
Beside cell 3 pump 3A		0.0	"
K-402-7 Cell Floor	10-29-47		
Beside cell 4 pump 2A		0.0	"
Beside cell 7 pump 2B		0.0	"
K-402-8 Cell Floor	10-29-47		
Beside cell 6 pump 1B		0.0	"
Beside cell 1 pump 6B		0.0	"
K-402-9 Cell Floor	10-29-47		
Beside cell 4 pump 5A		0.0	"
Beside cell 9 pump 1A		0.1	"
K-402-1 Pipe Gallery	10-30-47		
On catwalk at upper evacuation valve cell 10		0.1	"
Top of housing at A inlet valve cell 2		0.0	"
K-402-2 Pipe Gallery	10-30-47		
Top of housing at B bypass valve cell 9		0.1	"
On catwalk at B inlet valve cell 2		0.0	"
K-402-3 Pipe Gallery	10-30-47		
Top of housing at A inlet valve cell 3		0.0	"
On catwalk at B inverse recycle valve cell 8		0.1	"
K-402-4 Pipe Gallery	10-30-47		
Top of housing at A inlet valve cell 7		0.1	"
Service gallery at feed filter		0.1	"
K-402-6 Pipe Gallery	10-30-47		
Top of housing at A normal building outlet valve		0.0	"
On catwalk at A outlet valve cell 8		0.0	"

RESTRICTED

RESTRICTED

-10-

K-402-7 Pipe Gallery

10-30-47

Top of housing at B inlet valve cell 8  
On catwalk at evacuation valve cell 2

0.0 Alpha counts/min/ft<sup>3</sup>  
0.1 "

K-402-8 Pipe Gallery

10-30-47

Top of housing at A inlet valve cell 3  
On catwalk at B inverse recycle valve cell 4

0.0 "  
0.0 "

K-402-9 Pipe Gallery

10-30-47

On catwalk at cells 7 & 8 coolant pump pit door  
Top of housing at B outlet valve cell 1

0.0 "  
0.2 "

Note: For all samples taken on the cell floor and on the operating floor the inlet of the sampling instrument was 2 feet above the floor.

For all samples taken in the pipe gallery the inlet of the sampling instrument was 2 feet above the catwalk or the insulation on the pipes.

H. J. Gilbert

H. J. Gilbert

Approved:

W. C. Hartman

W. C. Hartman

JEP/nf

RESTRICTED

43

RESTRICTED

CASCADE SERVICES DEPARTMENT

PROCESS LABORATORY

RADIATION SURVEY

HEALTH SURVEY REPORT

Date of Issue November 5, 1947

DISTRIBUTION LIST

Mr. L. G. Bamor  
Mr. S. C. Barnett  
Dr. C. K. Beck  
Dr. M. J. Costello  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Mr. W. B. Kumes  
Mr. M. S. Lizzo  
Mr. J. A. Marshall

Mr. H. M. Preuss  
Mr. M. F. Schwenn  
Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. S. Visner ✓  
Mr. L. C. Willson  
Mr. R. A. Winkel  
Filo

RESTRICTED

RESTRICTED

HEALTH SURVEY REPORT

To: Mr. G. T. E. Shelden  
Location: K-303-7

Date: November 4, 1947

10-28-47 In the K-1301 conversion room beta-gamma determinations on the heaters, cold traps, and reactors were all zero.

In K-1212 in a check on six (6) diffusion pumps all beta-gamma determinations were zero.

10-30-47 Beta-gamma determinations on the cylinders in K-631 were all zero.

Beta-gamma determinations on the cylinders in K-131 varied from 0.007 to 0.010 and averaged 0.009 R/8 hours.

Air samples of air-borne alpha-active dust were as follows:

K-303-7 R.W. Station, seven	10-27-47	0.1	Alpha counts/min/ft <sup>3</sup>
east of withdrawal	10-28-47	0.1	"
manifolds	10-29-47	0.7	"
	10-30-47	0.1	"
	10-31-47	0.5	"

K-1301 outside of weighing room door	10-29-47	0.1	"
K-1301 seal chp	10-29-47	0.0	"

K-500-3 Operating Floor, Kinney Pumps 10-27-47  
Requested by Mr. R. A. Winkel

Pump SV-3, oil being added, 2 inches from exhaust	0.2	"
Pump SV-2, oil being added, 2 inches from exhaust	0.5	"
Pump SV-1, oil being added, 2 inches from exhaust	0.5	"

K-107-C, Cell 5 IBM Tests 10-24-47  
Requested by Mr. L. F. Haeco

Making initial cut and soldering in connection to test instrument, stage 4	0.0	"
Disconnecting test instrument and resoldering line, stage 4	0.0	"
Making initial cut and soldering in connection to test instrument, stage 5	0.0	"
Complete operation on IBM, stage 6	0.1	"

RESTRICTED

45



RESTRICTED

-2-

K-705-3 Cell 3 DBM Tests 10-24-47  
Requested by Mr. L. F. Haese

Background sample in center of cell enclosure	0.0	Alpha counts/min/ft <sup>3</sup>
Making initial cut in line and soldering in connection to test instrument	0.0	"
Disconnecting test instrument and re-soldering line	0.0	"
Making initial cut in line and soldering in connection to test instrument	0.0	"
Disconnecting test instrument and re-soldering line	0.0	"

K-308-2 Cell 6 DBM Tests 10-29-47  
Requested by Mr. L. F. Haese

Background sample in center of cell enclosure	0.0	"
Complete operation on DBM stage 1, 6 inches from operation	0.0	"
Making initial cut and soldering in connection to test instrument, 6 inches from operation	0.1	"
Disconnecting test instrument and re-soldering line, 6 inches from operation	0.3	"
Making initial cut in line, 6 inches away	1.0	"

K-181 Food Room 10-29-47  
Requested by Mr. L. G. Willson

While bath B feed tube #2 was being disconnected and immediately there after, 4 inches from tube	3.2	"
While bath B feed tube #4 was being disconnected and immediately there after, 4 inches from tube	1.3	"
Bath A, 2 inches from each feed tube while each tube was being disconnected	0.6	"

K-302-3 Operating Floor 10-22-47

Beside cells 9 & 10 lube oil lines	0.0	"
Inside of line recorder station at tube rack A	0.0	"
Beside cells 1 & 2 coolant pumps	0.1	"

RESTRICTED

46

RESTRICTED

-3-

K-302-3 Operating Floor	10-22-47		
At building panel board	0.1	Alpha counts/min/ft <sup>3</sup>	
Inside of line recorder station			
at manifold pump	0.2	"	
Above A inlet valve cell 7	0.1	"	
K-302-2 Operating Floor	10-22-47		
Beside Kinney pump SV-3	0.0	"	
Inside of line recorder station under			
sample manifold	0.1	"	
Beside cells 1 & 2 coolant pumps	0.0	"	
K-302-1 Operating Floor	10-22-47		
Above B spare building bypass valve	0.0	"	
Inside of line recorder station			
at tube rack A	0.0	"	
At cells 5 & 7 panel boards	0.1	"	
K-301-3 Operating Floor	10-22-47		
Beside cell 5 coolant pump	0.0	"	
Inside of line recorder station			
at sample manifold	0.0	"	
At building panel board	0.0	"	
K-301-1 Operating Floor	10-22-47		
Inside of line recorder station			
at tube rack A	0.0	"	
Above A bypass valve cell 2	0.0	"	
Center of building above cells 7 & 8	0.0	"	
K-301-3 Operating Floor	10-22-47		
Above A inlet valve cell 6	0.0	"	
Inside of line recorder station at			
manifold pump	0.1	"	
At cell 1 coolant pump	0.1	"	
K-301-2 Operating Floor	10-22-47		
At building panel board	0.0	"	
Inside of line recorder station			
at tube rack A	0.0	"	
Above A outlet valve cell 7	0.0	"	

RESTRICTED

47

~~RESTRICTED~~

-4-

K-301-1 Operating Floor

10-22-47

Above B outlet valve cell 6	0.0	Alpha counts/min./ftS
Inside of line recorder station	0.0	"
at sample manifold pump	0.0	"
Above B spare building outlet valve	0.0	"

K-309-1 Operating Floor

10-22-47

Beside cells 1 & 2 coolant pumps	0.0	"
Inside of line recorder station	0.1	"
at tube rack A	0.3	"
Beside Kinney pump SV-3		

K-309-2 Operating Floor

10-23-47

Beside cell 1 & 2 coolant pumps	0.1	"
Inside of line recorder station	0.2	"
at sample manifold pump	0.1	"
Above B inlet valve cell 5		

K-309-3 Operating Floor

10-23-47

At carbon trap S-3	0.1	"
Inside of line recorder station	0.3	"
at sample manifold	0.2	"
Above B spare building bypass valve		

K-310-1 Operating Floor

10-23-47

At cell 1 coolant pump	0.1	"
Inside of line recorder station	0.1	"
at tube rack A	0.0	"
At cells 5 & 6 lube oil lines		

K-310-2 Operating Floor

10-23-47

Above B inverse recycle valve cell 8	0.0	"
Inside of line recorder station	0.1	"
at manifold pump	0.1	"
Above A inverse recycle valve cell 1		

K-310-3 Operating Floor

10-23-47

Above A building inlet valve	0.0	"
Inside of line recorder station	0.1	"
at tube rack A	0.0	"
Beside cells 5 & 6 coolant pumps		

~~RESTRICTED~~

48

~~RESTRICTED~~

-5-

K-311-1 Operating Floor

10-23-47

Inside of line recorder station  
at sample manifold pump  
Above A outlet valve coil 7  
At building panel board

0.0 Alpha counts/min/ft<sup>3</sup>  
0.0 "  
0.1 "

K-311-1 Cell Floor

10-25-47

Beside cell 7 pump 3A  
Beside cell 2 pump 5B

0.0 "  
0.0 "

Note: For all samples marked "Operating Floor" the inlet of the sampling instrument was 2 feet above the floor.

R. J. Clouse  
R. J. Clouse

Approved: W. C. Hartman  
W. C. Hartman

JEF/ef

~~RESTRICTED~~

RESTRICTED

PW  
v.8

CASCADE SERVICES DEPARTMENT  
PROCESS LABORATORY  
RADIATION SURVEY

HEALTH SURVEY REPORT

Date of Issue October 28, 1947

DISTRIBUTION LIST

- |                    |                      |
|--------------------|----------------------|
| Mr. L. G. Bamer    | Mr. H. M. Preuss     |
| Mr. S. C. Barnett  | Mr. M. F. Schwenn    |
| Dr. C. K. Beck     | Mr. M. P. Seyfried   |
| Dr. M. J. Costello | Mr. G. T. E. Sheldon |
| Mr. W. C. Hartman  | Mr. B. Speyers       |
| Mr. A. P. Huber    | Mr. S. Visner        |
| Mr. W. B. Humes    | Mr. L. C. Willson    |
| Mr. M. S. Lisco    | Mr. R. A. Winkel     |
| Mr. J. A. Marshall | File                 |

RESTRICTED

~~RESTRICTED~~

HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location: K-303-7

Date: October 28, 1947

10-20-47 In the K-1301 conversion room beta-gamma determinations on the cold traps, heaters, and reactors were all zero.

10-21-47 Beta-gamma measurements on the decontamination tanks in the K-1303 decontamination room varied from 0.000 to 0.021 with an average of 0.005 R/8 hours.

In K-631 beta-gamma measurements on the carbon traps and cylinders were all zero.

In K-131 beta-gamma measurements on the cylinders varied from 0.000 to 0.021 and averaged 0.009 R/8 hours.

10-22-47 In the K-1303 decontamination room beta-gamma measurements on the decontamination tanks varied from 0.000 to 0.022 and averaged 0.004 R/8 hours.

10-23-47 Beta-gamma measurements on the cylinders and carbon traps in K-631 were all zero.

Beta-gamma measurements on the cylinders in K-131 varied from 0.000 to 0.010 with an average of 0.004 R/8 hours.

Air samples of air-borne alpha-active dust were as follow:

K-303-7 PW Station, seven feet east of withdrawal manifolds	10-17-47	0.2	Alpha counts/min/ft <sup>3</sup>
	10-20-47	2.8	
	10-21-47	0.1	
	10-22-47	0.1	
	10-23-47	0.1	
	10-24-47	0.0	
K-1301 outside of weighing room door	10-20-47	1.0	"
	10-22-47	0.2	"
K-1303 decontamination room, between tanks A & E	10-20-47	0.9	"
	10-22-47	0.1	"

RESTRICTED

RESTRICTED

-2-

K-631 near withdrawal manifolds	10-21-47	0.1	Alpha counts/min/ft <sup>3</sup>
K-131 between units A & B	10-21-47	0.6	"
K-1401 seal shop	10-21-47	0.0	"
K-305-10 Cell Floor	10-16-47		
Beside cell 1 pump 4A		0.0	"
Beside cell 7 pump 2A		0.0	"
K-305-9 Cell Floor	10-16-47		
Beside cell 8 pump 4A		0.0	"
Beside cell 2 pump 4A		0.0	"
K-305-8 Cell Floor	10-16-47		
Beside cell 2 pump 4A		0.0	"
Beside cell 8 pump 4A		0.0	"
K-305-7 Cell Floor	10-16-47		
Beside cell 2 pump 3B		0.0	"
Beside cell 8 pump 4A		0.0	"
K-305-6 Cell Floor	10-16-47		
Beside cell 1 pump 1B		0.0	"
Beside cell 7 pump 2A		0.0	"
K-305-5 Cell Floor	10-16-47		
Beside cell 6 pump 2A		0.0	"
Beside cell 2 pump 2B		0.0	"
K-305-4 Cell Floor	10-16-47		
Beside cell 2 pump 6A		0.0	"
Beside cell 9 pump 5A		0.0	"
K-305-3 Cell Floor	10-16-47		
Beside cell 10 pump 6A		0.0	"
Beside cell 1 pump 4B		0.0	"
K-305-2 Cell Floor	10-16-47		
Beside cell 2 pump 6A		0.0	"
Beside cell 7 pump 3A		0.0	"
K-305-1 Cell Floor	10-16-47		
Beside cell 4 pump 1B		0.0	"
In escape alley at front door		0.0	"
K-304-5 Cell Floor	10-20-47		
Beside cell 9 pump 4A		0.0	"
Beside cell 1 pump 5A		0.0	"

RESTRICTED

RESTRICTED

-3-

K-304-4 Cell Floor	10-20-47	0.0	Alpha counts/min/ft <sup>3</sup>
Beside cell 3 pump 3B		0.0	"
Beside cell 8 pump 4B			
K-304-3 Cell Floor	10-20-47	0.0	"
Beside cell 9 pump 4A		0.0	"
Beside cell 2 pump 3A			
K-304-2 Cell Floor	10-20-47	0.0	"
Beside cell 1 pump 4A		0.0	"
Beside cell 10 pump 6B			
K-304-1 Cell Floor	10-20-47	0.0	"
Beside cell 7 pump 6A		0.0	"
Beside cell 4 pump 5A			
K-305-10 Pipe Gallery	10-17-47	0.0	"
Above Cell 4		0.1	"
Above Cell 7			
K-305-9 Pipe Gallery	10-17-47	0.0	"
Above cell 8		0.0	"
Center of service gallery			
K-305-8 Pipe Gallery	10-17-47	0.0	"
Above cell 6		0.0	"
Above cell 9			
K-305-7 Pipe Gallery	10-17-47	0.0	"
Above cell 10		0.0	"
Above cell 1			
K-305-6 Pipe Gallery	10-17-47	0.0	"
Above cell 1		0.0	"
Above cell 7			
K-305-5 Pipe Gallery	10-17-47	0.0	"
Above cell 10		0.0	"
Above cell 2			
K-305-4 Pipe Gallery	10-17-47	0.0	"
Above cell 4		0.1	"
Above cell 7			
K-305-3 Pipe Gallery	10-17-47	0.0	"
Above cell 8		0.1	"
Beside building B inlet valve			

RESTRICTED



-4-

K-305-2 Pipe Gallery	10-17-47	0.0	Alpha counts/min/ft <sup>3</sup>
Above Cell 4		0.0	"
Above Cell 5		0.0	"
K-305-1 Pipe Gallery	10-17-47	0.0	"
Above Cell 10		0.0	"
Center of service gallery		0.0	"
K-304-5 Pipe Gallery	10-17-47	0.0	"
Above Cell 1		0.0	"
Above Cell 5		0.0	"
K-304-4 Pipe Gallery			
Above Cell 8	10-17-47	0.0	"
At C-216 manifold	10-20-47	0.0	"
K-304-3 Pipe Gallery	10-20-47		
Beside B bypass valve cell 4		0.0	"
At C-216 disposal valve cell 9		0.0	"
K-304-2 Pipe Gallery	10-20-47		
Beside A outlet valve cell 8		0.0	"
Beside A outlet valve cell 1		0.0	"
K-304-1 Pipe Gallery	10-20-47		
Beside B bypass valve cell 4		0.0	"
Beside A outlet valve cell 9		0.0	"
K-303-10 Operating Floor	10-20-47		
Above A normal building outlet valve		0.2	"
Inside of line recorder station		0.1	"
Beside cells 7 & 8 coolant pumps		0.0	"
K-303-7 Operating Floor			
Above B spare building outlet valve	10-20-47	0.0	"
Inside of line recorder station at			
tube rack A	10-21-47	0.1	"
Above A inlet valve Cell 8	10-21-47	0.0	"
K-303-6 Operating Floor	10-21-47		
Beside cells 9 & 10 coolant pumps		0.0	"
Inside of line recorder station at			
sample manifold		0.0	"
Above A normal building bypass valve		0.0	"
K-303-5 Operating Floor			
Beside cells 1 & 2 coolant pumps		0.0	"
Inside of line recorder station			
at sample manifold		0.1	"
Above B inverse recycle valve cell 8		0.0	"

~~RESTRICTED~~

-5-

K-303-4 Operating Floor	10-21-47		
At cell 9 panel board		0.0	Alpha counts/min/ft <sup>3</sup>
Inside of line recorder station		0.0	"
at tube rack A		0.0	"
Above A bypass valve cell 1			
K-303-5 Operating Floor	10-21-47		
Above B normal building inlet valve		0.0	"
Inside of line recorder station at		0.1	"
sample manifold		0.0	"
Between cells 9 & 10 panel boards			
K-303-2 Operating Floor	10-21-47		
Beside Kinney pump SV-3		0.0	"
Inside of line recorder station		0.0	"
at tube rack A		0.1	"
Above A inverse recycle valve cell 3			
K-303-1 Operating Floor	10-21-47		
Above A outlet valve cell 2		0.1	"
Inside of line recorder station		0.0	"
under sample manifold		0.2	"
Beside cells 7 & 8 coolant pumps			

Note: For all samples taken on the cell floor the inlet of the sampling instrument was 2 feet above the floor.

For all samples taken in the pipe gallery the inlet of the sampling instrument was 3 feet above the insulation on the cell and 1 foot or less from the insulation on the pipes, unless otherwise noted.

For all samples taken on the operating floor the inlet of the sampling instrument was 2 feet above the floor.

H. J. Culbert  
H. J. Culbert

Approved:

W. C. Hartman  
W. C. Hartman

JHP/nf

~~RESTRICTED~~

55

RESTRICTED

CASCADE SERVICES DEPARTMENT

PROCESS LABORATORY

RADIATION SURVEY

HEALTH SURVEY REPORT

Date of Issue October 22, 1947

DISTRIBUTION LIST

Mr. L. G. Bamer  
Mr. S. C. Barnett  
Dr. C. K. Beck  
Dr. M. J. Costello  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Mr. W. B. Humes  
Mr. M. S. Lisco  
Mr. J. A. Marshall

Mr. E. M. Preuss  
Mr. M. F. Schwenn  
Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. S. Visner  
Mr. L. C. Willson  
File

RESTRICTED

RESTRICTED

HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location: K-303-7

Date: October 21, 1947

10-13-47 Beta-gamma measurements on the reactors, heaters, and cold traps in the K-1301 conversion room were all zero.

In the K-1303 decontamination room beta-gamma measurements on the tool table and work bench were all zero; those made on the decontamination tanks ranged from 0.000 to 0.034 and averaged 0.003 R/8 hours.

10-14-47 In K-631 beta-gamma determinations on the cylinders and carbon traps were all zero.

In K-131 beta-gamma determinations on the cylinders and on the ends of the vaporization units ranged from 0.003 to 0.028 with an average of 0.009 R/8 hours.

Air samples of air borne alpha-active dust were as follows:

K-303-7 P.W. Station seven feet east of withdrawal manifolds	10-10-47	0.0	Alpha counts/min/ft <sup>3</sup>
	10-13-47	0.0	"
	10-14-47	0.0	"
	10-15-47	0.5	"
	10-16-47	0.2	"
K-1303 decontamination room, between tanks A & E	10-13-47	0.1	"
K-1301 outside weighing room door	10-13-47	0.7	"
K-1405 center of downstairs room	10-13-47	0.2	"
K-1405 center of laboratory	10-13-47	0.1	"
K-631 near withdrawal manifolds	10-14-47	0.0	"
K-131 west end of cylinder racks	10-14-47	0.0	"
K-1401 AC pump shop	10-14-47	0.1	"
K-1401 seal shop	10-14-47	0.1	"
K-402-S, Cell 5 DBM Tests			
Requested by Mr. L. F. Haase	10-15-47		
Complete operation on DBM, stage 1		0.0	"

RESTRICTED

~~RESTRICTED~~

-2-

K-309-2, Cell 2 DBM Tests, all samples taken 6 inches from operation  
Requested by Mr. L. F. Haess 10-15-47

Disconnecting test instrument and resoldering DBM, stage 2	0.2	Alpha counts/min/ft <sup>3</sup>
Complete operation on DBM, stage 3	0.1	"
Making initial cut and soldering in connection to test instrument, stage 4	0.1	"
Disconnecting test instrument and resoldering DBM, stage 4	0.1	"
Initial cut on DBM line, stage 5	1.6	"
Resoldering DBM line, stage 5	1.1	"
Complete operation on DBM, stage 6	0.1	"

K-306-7 Line Recorder Station 10-15-47

15 inches from manifold, hoke tube being disconnected after inventory sample had been taken

1.2

"

15 inches from manifold, hoke tube being disconnected after inventory sample had been taken

2.2

"

K-301-6 Line Recorder Station 10-15-47

15 inches from manifold, hoke tube being disconnected after inventory sample had been taken

0.4

"

K-310-1 Operating floor, Kinney pumps being drained and filled.  
Requested by Mr. R. A. Winkel 10-15-47

Pump SV-3, 6 inches from oil drain pipe	0.1	"
Pump SV-1, 6 inches from oil drain pipe	0.2	"

K-309-3 Operating floor, Kinney pumps being drained and filled.  
Requested by Mr. R. A. Winkel 10-15-47

Pump SV-3, 6 inches from exhaust	0.2	"
Pump SV-2, 6 inches from exhaust	0.1	"

K-301-3 Operating floor, Kinney pumps being drained and filled.  
Requested by Mr. R. A. Winkel 10-16-47

Pump SV-3, 2 inches from oil drain pipe	0.1	"
---	-----	---

K-302-1 Operating floor Kinney pumps being drained and filled.  
Requested by Mr. R. A. Winkel 10-16-47

Pump SV-1, 2 inches from oil drain pipe	0.1	"
Pump SV-2, 2 inches from exhaust	0.0	"
Pump SV-3, 2 inches from exhaust	0.2	"

~~RESTRICTED~~

58

RESTRICTED

-3-

K-302-2 Operating floor, Kinney pumps being drained and filled.  
Requested by Mr. R. A. Winkel 10-16-47

Pump SV-2, 2 inches from oil drain pipe 0.2 Alpha counts/min/ft<sup>3</sup>

K-302-4 Operating floor, Kinney pumps being drained and filled.  
Requested by Mr. R. A. Winkel 10-16-47

Pump SV-1, 2 inches from exhaust 0.0 "

K-302-5 Operating floor, Kinney pumps being drained and filled.  
Requested by Mr. R. A. Winkel 10-16-47

Pump SV-1, 2 inches from oil drain pipe 0.0 "

Pump SV-3, 2 inches from exhaust 0.4 "

K-303-1 Operating floor, Kinney pumps being drained and filled.  
Requested by Mr. R. A. Winkel 10-16-47

Pump SV-3, 2 inches from oil drain pipe 0.0 "

Pump SV-1, 2 inches from exhaust 0.1 "

K-305-3 Operating floor 10-13-47

Above A bypass valve Cell 1 0.1 "

Inside of Line Recorder Station 0.0 "

K-305-2 Operating floor 10-13-47

Beside Cells 3 & 4 coolant pumps 0.0 "

In front of Cells 9 & 10 panel boards 0.1 "

K-305-1 Operating floor 10-13-47

Beside Kinney pump SV-3 0.0 "

Above A spare building bypass valve 0.1 "

K-304-5 Operating floor 10-13-47

Inside of Line Recorder Station 0.1 "

Above A inlet valve Cell 9 0.1 "

K-304-4 Operating floor 10-13-47

Above B inlet valve Cell 10 0.0 "

Above Cell 3 0.0 "

K-304-3 Operating floor 10-13-47

Beside Cells 1 & 2 coolant pumps 0.2 "

Beside Kinney pump SV-3 0.0 "

K-304-2 Operating floor 10-13-47

Inside of Line Recorder Station 0.1 "

Above A inlet valve Cell 9 0.0 "

RESTRICTED

59

RESTRICTED

-4-

K-304-1 Operating Floor	10-13-47		
Above A bypass valve Cell 8		0.1	Alpha counts/min/ft <sup>3</sup>
Above A spare building bypass valve		0.0	"
K-303-10 Cell Floor	10-13-47		
Escape alley door		0.1	"
Escape alley between Cells 3 & 4		0.0	"
K-303-9 Cell Floor	10-13-47		
Beside Cell 4 pump 2A		0.0	"
In escape alley Cell 3 pump 6B		0.0	"
K-312-3 Pipe Gallery	10-14-47		
Above cold trap		0.0	"
Center of pipe gallery		0.1	"
K-312-3 Cell Floor	10-14-47		
At head of stairs to basement		0.0	"
In alley between Cells 10 & 12		0.0	"
K-312-2 Pipe Gallery	10-14-47		
Above Cell 15		0.0	"
Above Cell 2		0.0	"
K-312-2 Cell Floor	10-14-47		
Beside Cell 3		0.0	"
Beside Cell 17		0.1	"
K-312-1 Pipe Gallery	10-14-47		
Above Cells 1 & 2		0.0	"
Above Cell 11		0.1	"
K-312-1 Cell Floor	10-14-47		
Center alley at basement stairs		0.1	"
Beside Cell 5		0.0	"
K-306-4 Pipe Gallery	10-15-47		
Above Cell 5		0.0	"
Above Cells 1 & 2		0.1	"
K-306-4 Cell Floor	10-14-47		
Escape alley between Cells 3 & 4		0.1	"
Withdrawal alley Cell 11		0.0	"
K-306-3 Pipe Gallery	10-15-47		
Above Cell 3		0.1	"
Above Cell 9		0.0	"
K-306-3 Cell Floor	10-14-47		
Escape alley between cells 9 & 10		0.1	"
At escape alley door		0.1	"

RESTRICTED

60

R E S T R I C T E D

-5-

K-306-1 Pipe Gallery	10-15-47	0.1	Alpha counts/min/ft <sup>3</sup>
Above intersectional Cell		0.0	"
Above Cell 11			
K-306-1 Cell Floor	10-15-47		
In escape alley beside Cell 1.		0.0	"
In escape alley beside Cell 5		0.0	"
K-306-12 Pipe Gallery	10-15-47		
Above Cell 10		0.0	"
Center of service gallery		0.0	"
K-306-12 Cell Floor	10-15-47		
Front of building		0.0	"
In withdrawal alley Cell 9		0.1	"
K-306-11 Pipe Gallery	10-15-47		
Center of service gallery		0.0	"
Above Cell 5		0.1	"
K-306-11 Cell Floor	10-15-47		
In withdrawal alley Cell 10		0.0	"
In escape alley between 1 & 2		0.1	"

Note: For all samples taken on the cell floor the inlet of the sampling instrument was 2 feet above the floor.

For all samples taken in the pipe gallery the inlet of the sampling instrument was 3 feet above the insulation on the cell and 1 foot or less from the insulation on the pipes, unless otherwise noted.

For all samples taken on the operating floor the inlet of the sampling instrument was 2 feet above the floor, unless otherwise noted.

H. J. Culbert

H. J. Culbert

Approved:

W. C. Hartman

W. C. Hartman

JHP/nf

R E S T R I C T E D

61



RESTRICTED

CASCADE SERVICES DEPARTMENT

PROCESS LABORATORY

RADIATION SURVEY

HEALTH SURVEY REPORT

Date of Issue October 14, 1947

DISTRIBUTION LIST

Mr. L. G. Pamer  
Mr. S. C. Barnett  
Dr. C. K. Beck  
Dr. M. J. Costello  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Mr. W. B. Humes  
Mr. M. S. Lisso  
Mr. J. A. Marshall

Mr. H. M. Preuss  
Mr. M. F. Schwenn  
Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. S. Vigner ✓  
Mr. L. C. Willson  
File

RESTRICTED

RESTRICTED

HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location: K-303-7

Date: October 14, 1947

10-6-47 In the K-1303 decontamination room beta-gamma determinations on the work bench, tool table, and decontamination tanks varied from 0.000 to 0.007 with an average of 0.002 R/8 hours.

In the K-1301 conversion room beta-gamma determinations on the heaters, cold traps, and reactors were all zero.

10-7-47 Beta-gamma determinations on the cylinders and carbon traps in K-631 were all zero.

Beta-gamma determinations on the cylinders in K-131 varied from 0.007 to 0.017 and averaged 0.010 R/8 hours.

10-8-47 Beta-gamma measurements on the decontamination tanks, tool table, and work bench in the K-1303 decontamination room varied from 0.000 to 0.008 and averaged 0.001 R/8 hours.

All beta-gamma measurements on the reactors, cold traps, and heaters in the K-1301 conversion room were zero.

10-9-47 In K-631 all beta-gamma determinations on the cylinders were zero.

In K-131 the beta-gamma determinations on the cylinders varied from 0.000 to 0.031 with an average of 0.013 R/8 hours.

Air samples of air-borne alpha-active dusts taken during the week were as follows:

K-303-7 P.W. Station seven feet east of withdrawal manifolds	10-3-47	0.0	Alpha counts/min/ft <sup>3</sup>
	10-6-47	0.0	"
	10-7-47	0.1	"
	10-8-47	0.0	"
	10-9-47	0.1	"
K-1301 outside of weighing room door	10-6-47	0.0	"
	10-8-47	1.3	"
K-1303 decontamination room, between tanks A & E	10-6-47	0.2	"
	10-8-47	0.2	"
K-1405 downstairs room, center of	10-6-47	0.0	"
K-1405 laboratory, center of	10-6-47	0.3	"

RESTRICTED 63

-2-

## K-310-1, Cell 1 DBM Changes

Requested by Mr. L. F. Haese

10-6-47

Background, center of cell enclosure		0.0	Alpha counts/min/ft <sup>2</sup>
Complete DBM change at stage 1		0.0	"
Making initial out and soldering in connection to test instrument stage 2		0.0	"
Disconnecting test instrument and re-soldering DBM, stage 3		0.0	"
Initial out on stage 4 DBM		0.0	"
Disconnecting test instrument and re-soldering DBM, stage 5		0.0	"
Complete DBM change at stage 6		0.0	"
Residual, at center of cell enclosure		0.0	"
K-631 near withdrawal manifolds	10-7-47	0.0	"
	10-9-47	0.0	"
K-131 near vaporization baths	10-7-47	0.0	"
	10-9-47	0.0	"
K-310-3 Cell 3 seal change pump 6A	10-3-47		
Two feet from seal before old seal was removed		0.0	"
Two feet from seal while old seal being removed		0.1	"
Two feet from seal, shaft being washed and new seal being installed		0.0	"
K-310-3 Cell 5 seal change pump 3B	10-3-47		
Two feet from seal while new seal being installed		0.0	"
Two feet from seal after new seal was installed		0.0	"
K-306-5 Operating floor	10-3-47		
Near front of building		0.0	"
Near center of building		0.0	"
Near back of building		0.0	"
K-306-2 Operating floor	10-3-47		
Near front of building		0.0	"
Near center of building		0.0	"
Near back of building		0.0	"
K-306-2 Pipe Gallery			
Above cell 13 pump 1B		0.0	"
Above cell 17 pump 5B		0.0	"
Above cell 3 pump 1B		0.0	"
K-306-2 Cell floor			
Cell 1 between pumps 1B and 2A		0.0	"
Cell 5 between pumps 2A and 3B		0.0	"
Cell 11 pump 3B		0.0	"
K-312-3 Operating floor	10-9-47		
Above B inlet valve and B bypass valve cell 4		0.0	"
Center of floor between panel boards for cells 15 and 16		0.0	"

~~RESTRICTED~~

64

-3-

K-312-2 Operating floor	10-9-47		
Between tube racks in line recorder station		0.0	Alpha. counts/min/FtS
Center of floor between panel boards for			
cells 19, 20, 21, and 22		0.0	"
K-312-1 Operating floor	10-9-47		
In front of building board		0.0	"
Beside coolant pumps in center of building		0.0	"
K-306-4 Operating floor	10-9-47		
Beside Kinney pump SV #1		0.0	"
In front of cell 12 panel board		0.0	"
K-306-3 Operating floor			
Between panel boards of cells 1 and 2		0.0	"
Beside coolant pumps, cells 13 and 14		0.0	"
K-306-1 Operating floor	10-9-47		
Inside of line recorder station		0.0	"
In front of cell 11 panel board		0.0	"
K-1004-D, Room 21	10-9-47		
Requested by Mr. H. A. Bernhardt			
Two feet south of hood on west table at			
chest height		0.0	"
North end of low table, 18 inches above			
top of table		0.0	"
Middle of east side of west table, 1 foot			
above top of table		0.0	"
K-1004-D, Room 05			
Requested by Mr. H. A. Bernhardt	10-10-47		
General air sample in room, no			
special operations proceeding		0.2	"

H. J. Culbert

H. J. Culbert

Approved:

W. C. Hartman

W. C. Hartman

JHP/nf

RESTRICTED

65

R E S T R I C T E D

CASCADE SERVICES DEPARTMENT

PROCESS LABORATORY

RADIATION SURVEY

HEALTH SURVEY REPORT

Date of Issue October 8, 1947

DISTRIBUTION LIST

Mr. L. G. Bamer  
Mr. S. C. Barnett  
Dr. C. K. Beck  
Dr. M. J. Costello  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Mr. W. B. Humes  
Mr. M. S. Lisso  
Mr. J. A. Marshall

Mr. H. M. Prouss  
Mr. M. F. Schworm  
Mr. M. P. Soyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. S. Visner ✓  
Mr. L. C. Willson  
File

R E S T R I C T E D

RESTRICTED

HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location: K-303-7

Date: October 7, 1947

9-29-47 In the K-1303 decontamination room beta-gamma measurements on the work bench, tool table, and decontamination tanks varied from 0.000 to 0.083 and averaged 0.008 R/8 hours.

In the K-1301 conversion room beta-gamma measurements on the cold traps, heaters, and reactors were all zero.

9-30-47 Beta-gamma measurements on the cylinders in K-131 varied from 0.007 to 0.017 with an average of 0.012 R/8 hours.

Beta-gamma measurements on the carbon traps and cylinders in K-631 were all zero.

10-1-47 Beta-gamma determinations on the decontamination tanks, work bench, and tool table in the K-1303 decontamination room varied from 0.000 to 0.028 with an average of 0.004 R/8 hours.

Beta-gamma determinations on the reactors, cold traps, and copper connections in the K-1301 conversion room were all zero.

Beta-gamma determinations made on "Buffalo Fans" in Warehouse C were all zero.

Air samples of air-borne alpha-active dusts taken during the week were as follows:

K-306-7 P.W. Station seven feet west of withdrawal manifolds	9-29-47	0.0	Alpha counts/min/ft <sup>3</sup>
	9-30-47	0.0	"
	10-1-47	0.0	"
	10-2-47	0.1	"
K-1303 decontamination room, between tanks A & E	9-29-47	0.7	"
	10-1-47	2.2	"
K-1301 outside of weighing room door	9-29-47	0.9	"
	10-1-47	0.1	"
K-1405 downstairs room	9-29-47	0.0	"
K-1405 laboratory	9-29-47	0.0	"
K-131 near vaporization baths	9-30-47	0.1	"
K-631 near withdrawal manifolds	9-30-47	0.1	"
K-301-2 cell 8 seal change, pump 5B	9-30-47		
Before seal opened, two feet to one side of seal		0.0	"
Body of seal being removed, part of process seal still in place, two feet to one side of seal		0.9	"

RESTRICTED

67

K-301-2 (Cont'd.)

Old seal removed, gas blowing out around shaft, two feet to one side of seal.

0.7 Alpha counts/min/ft<sup>3</sup>

K-301-2 cell 8 seal change, pump 6A 9-30-47

Old seal being removed, two feet to one side of seal

10.6 "

Old seal removed, shaft of impeller being washed with trichloroethylene, two feet to one side of seal

0.1 "

K-306-6

Operating floor 10-1-47

End of cell 1 panel board

0.0 "

Ten feet east of cell 10 panel board

0.0 "

Ten feet northeast of cell 13 panel board

0.0 "

Cell floor 10-2-47

North end of cell 1 pump 4A

0.0 "

Between cell 7 pump 4B and cell 8 pump 3B

0.0 "

South end of cell 12 pump 4A

0.0 "

Pipe gallery 10-2-47

Above cell 14 pump 5B

0.0 "

Between cells 9 and 10

0.0 "

Above cell 3 pump 5B

0.0 "

K-306-6

Cell floor 10-2-47

Cell 1 between pumps 1B and 2A

0.0 "

Between cells 7 and 8 in escape alley

0.0 "

Cell 12 pump 2A

0.0 "

Pipe gallery 10-2-47

Above cell 12 pump 1B

0.0 "

Center of building

0.0 "

Above cell 2 pump 1B

0.0 "

H. J. Culbert

H. J. Culbert

Approved:

W. C. Hartman

W. C. Hartman

JRP/nf

See Last Page  
9-48

R E S T R I C T E D

CASCADE SERVICES DEPARTMENT

PROCESS LABORATORY

RADIATION SURVEY

HEALTH SURVEY REPORT

Date of Issue September 30, 1947

DISTRIBUTION LIST

Mr. L. G. Bamer  
Mr. S. C. Barnett  
Dr. C. K. Beck  
Dr. M. J. Costello  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Mr. W. B. Humes  
Mr. M. S. Lisso  
Mr. J. A. Marshall

Mr. H. M. Preuss  
Mr. M. F. Schwenn  
Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. S. Visner ✓  
Mr. L. C. Willson  
File

R E S T R I C T E D



HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location: K-303-7

Date: September 30, 1947

9-22-47 In K-1303 in the decontamination room, beta-gamma measurements on the tool table, work bench, and decontamination tanks varied from 0.000 to 0.010 with an average of 0.004 R/8 hours.

9-23-47 Beta-gamma determinations on the reactors, heaters, and cold traps in the K-1301 conversion room were all zero.

Beta-gamma determinations on the cylinders and carbon traps in K-631 were all zero.

In K-131 beta-gamma measurements on the carbon traps were all zero, and those on the cylinders varied from 0.007 to 0.014 with an average of 0.010 R/8 hours.

9-24-47 Beta-gamma determinations on the reactors, cold traps, and heaters in the K-1301 conversion room were all zero.

Beta-gamma determinations on the work bench, tool table, and decontamination tanks in the K-1303 decontamination room varied from 0.000 to 0.062 and averaged 0.005 R/8 hours.

9-26-47 In the K-1301 conversion room beta-gamma measurements on the cold traps, heaters, and reactors were all zero.

In the K-1303 decontamination room, beta-gamma measurements on the work bench, tool table, and decontamination tanks varied from 0.000 to 0.034 and averaged 0.005 R/8 hours.

Beta-gamma determinations on the cylinders and carbon traps in K-631 were all zero.

Beta-gamma determinations on the cylinders in K-131 varied from 0.003 to 0.010 with an average of 0.007 R/8 hours.

Air samples of air-borne alpha-active dusts taken during the week were as follows:

K-306-7 P.m. Station seven feet	9-22-47	0.2	Alpha counts/min/ft <sup>3</sup>
west of withdrawal mani-	9-23-47	0.3	"
folds	9-24-47	0.1	"
	9-25-47	0.1	"
	9-26-47	0.1	"

RESTRICTED

~~RESTRICTED~~

-2-

K-1303 decontamination room	9-22-47	0.1	alpha counts/min/ft <sup>3</sup>
between tanks A & E	9-24-47	1.6	"
	9-26-47	1.1	"
K-131 near vaporization baths	9-23-47	0.1	"
	9-26-47	0.2	"
K-631 near drawoff manifold	9-23-47	0.0	"
	9-26-47	0.1	"
K-1401 AC pump shop	9-23-47	0.1	"
K-303-5, Cell #7, pulling pump	9-23-47		
Edge of opening while pump being pulled		365.8	"
After pump is pulled, 6 inches from			
impeller		21.3	"
K-1405 downstairs room	9-23-47	0.0	"
K-1405 laboratory	9-23-47	0.0	"
K-1301 outside of weighing room			
door	9-23-47	0.1	"
	9-24-47	0.1	"
	9-26-47	6.8	"
K-303-8 Operating floor	9-25-47		
In LRS at east end of panel board		0.0	"
Above cell 4 A inlet valve		0.0	"
By west entrance to CCR		0.0	"
K-303-9 Operating floor	9-25-47		
Above cell 5 B outlet valve		0.0	"
By north end of cell 3 panel board		0.1	"
In LRS at south west corner of west			
manifold		0.0	"

H. J. Culbert

H. J. Culbert

Approved:

W. C. Hartman

W. C. Hartman

JH/nf

~~RESTRICTED~~

71

WC  
gg8 ✓  
HG ✓

R E S T R I C T E D

CASCADE SERVICES DEPARTMENT

PROCESS LABORATORY

RADIATION SURVEY

HEALTH SURVEY REPORT

Date of Issue September 23, 1947

DISTRIBUTION LIST

Mr. L. G. Bamer  
Mr. S. C. Barnett  
Dr. C. K. Beck  
Dr. M. J. Costello  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Mr. W. B. Humes  
Dr. F. W. Hurd  
Mr. M. S. Lisao

Mr. J. A. Marshall  
Mr. H. M. Preuss  
Mr. M. F. Schwenn  
Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. S. Visner ✓  
Mr. L. C. Willson  
File

R E S T R I C T E D

R E S T R I C T E D

HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location: K-303-7

Date: September 23, 1947

9-15-47 In K-1303 the beta-gamma determinations on the decontamination tanks, work bench, and tool table in the decontamination room varied from 0.000 to 0.028 with an average of 0.003 R/8 hours.

In K-1301 the beta-gamma determinations on the furnaces, heaters, and reactors in the conversion room were all zero.

9-16-47 All beta-gamma determinations on the cylinders and carbon traps in K-631 were zero.

All beta-gamma determinations on the carbon traps in K-131 were zero; the ones made on the cylinders varied from 0.005 to 0.019 and averaged 0.010 R/8 hours.

9-17-47 In the decontamination room in K-1303, beta-gamma determinations on the tool table and decontamination tanks varied from 0.000 to 0.069 with an average of 0.008 R/8 hours.

In the conversion room in K-1303, all beta-gamma determinations were zero.

9-18-47 In K-631 on the cylinders and carbon traps all beta-gamma determinations were zero.

In K-131 the beta-gamma determinations on the carbon traps were all zero and those on the cylinders varied from 0.007 to 0.012 with an average of 0.011 R/8 hours.

9-19-47 The beta-gamma determinations made on the reactors, cold traps, and heaters in the conversion room in K-1301 were all zero.

The beta-gamma determinations made on the decontamination tanks and tool table in the decontamination room in K-1303 varied from 0.000 to 0.072 and averaged 0.009 R/8 hours.

Air samples of air-borne alpha-active dusts taken during the week were as follows:

K-306-7 P.W. Station seven feet west of withdrawal manifolds	9-15-47	0.0	Alpha counts/min/ft <sup>3</sup>
	9-16-47	0.1	"
	9-17-47	0.1	"
	9-18-47	0.1	"
	9-19-47	0.1	"

R E S T R I C T E D

R E S T R I C T E D

-2-

K-1301 outside of weighing room door	9-15-47	0.6	Alpha counts/min/ft <sup>3</sup>
	9-17-47	0.1	"
	9-19-47	0.0	"
K-1303 decontamination room	9-15-47	0.4	"
between tank A and E	9-17-47	0.2	"
	9-19-47	0.1	"
K-1401 laboratory	9-17-47	0.0	"
K-131 near vaporization baths	9-16-47	0.0	"
	9-18-47	0.8	"
K-631 near draw off manifold	9-16-47	0.0	"
	9-18-47	0.6	"
K-1401 retubing area	9-16-47	0.0	"
K-1401 AC pump shop	9-16-47	0.0	"
K-1405 laboratory	9-15-47	0.7	"
K-1303 Decontamination Room	9-15-47		
Requested by Mr. G. J. Selvin			
Three inches above tank L before solution was agitated with air		1.3	"
Three inches above tank L while solution was being agitated		4.2	"
Three inches above tank L after agitation of the solution was stopped		0.8	"
K-1303 Requested by Mr. H. M. Preuss	9-18-47		
Cubicle #4, one foot from pan evaporator with fan on		0.0	"
Cubicle #4, one foot from pan evaporator with fan off		1.4	"
Cubicle #3, one foot from evaporating unit with fan on		0.1	"
K-1405 Requested by Mr. H. M. Preuss	9-18-47		
Two feet from original alumina, dust rising from the alumina		32.3	"
Two feet from waste alumina, dust rising from the alumina		0.9	"

H. J. Culbert  
H. J. Culbert

Approved:

W. C. Hartman  
W. C. Hartman

JHP/nf

R E S T R I C T E D

74

R E S T R I C T E D

CASCADE SERVICES DEPARTMENT

PROCESS LABORATORY

RADIATION SURVEY

HEALTH SURVEY REPORT

Date of Issue September 9, 1947

DISTRIBUTION LIST

Mr. L. G. Bamer  
Mr. S. C. Barnett  
Dr. C. K. Beck  
Dr. M. J. Costello  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Dr. F. W. Hurd  
Mr. M. S. Lisso  
Mr. J. A. Marshall

Mr. H. M. Preuss  
Mr. M. P. Schwenn  
Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. S. Visner ✓  
Mr. L. C. Willson  
File

R E S T R I C T E D

R E S T R I C T E D

HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location: K-303-7

Date: September 9, 1947

- 9-2-47 Beta-gamma determinations on the cylinders and carbon traps in K-631 were all zero.
- In K-131 the beta-gamma measurements on the cylinders varied from 0.007 to 0.034 with an average of 0.019 R/8 hours.
- 9-3-47 Beta-gamma measurements on the decontamination tanks, work bench, and tool table in the decontamination room in K-1303 varied from 0.000 to 0.035 and averaged 0.003 R/8 hours.
- Beta-gamma measurements on the cold traps and reactors in the Conversion Room in K-1301 were all zero.
- 9-4-47 In K-631 beta-gamma measurements on the carbon traps and the cylinders were all zero.
- In K-131 beta-gamma measurements on the cylinders ranged from 0.005 to 0.021 with an average of 0.012 R/8 hours.
- 9-5-47 In the decontamination room in K-1303, beta-gamma determinations ranged from 0.000 to 0.016 and averaged 0.005 R/8 hours.
- Beta-gamma measurements on the cold traps, heaters, and reactors in the Conversion Room in K-1301 were all zero.

Air samples of air-borne alpha-active dusts taken during the week were as follows:

K-306-7 P.W. Station	9-1-47	0.1 Alpha counts/min/ft <sup>3</sup>	
	9-2-47	0.4	"
	9-3-47	0.3	"
	9-4-47	0.3	"
K-1410 near carbon-alumina separator	9-2-47	0.1	"
	9-4-47	0.1	"
K-631 near draw-off manifold	9-2-47	0.6	"
	9-4-47	0.1	"

R E S T R I C T E D

76

R E S T R I C T E D

-2-

K-131 near vaporization baths	9-2-47	0.1 Alpha counts/min/ft <sup>3</sup>	"
	9-4-47	0.2	"
K-1401 retubing area	9-2-47	0.0	"
K-1401 AC Pump Shop	9-2-47	0.0	"
K-1301 Outside weighing room	8-29-47	0.1	"
	9-5-47	0.1	"
K-1303 Decontamination Room			
cylinders being opened	8-29-47	12.6	"
normal operation	9-5-47	0.2	"
F-01 in work area	9-2-47	0.2	"
	9-2-47	0.6	"
	9-2-47	0.0	"
	9-4-47	0.8	"
	9-4-47	0.0	"
	9-4-47	0.0	"
K-306-1 cylinder repair shop			
no operations proceeding	9-3-47	0.1	"
K-305-12			
no operations proceeding	9-3-47	0.1	"
K-306-4 Cell #6, instrument change	9-3-47	0.1	"
	9-3-47	0.0	"
K-306-5 Cell #14, instrument change	9-3-47	0.1	"
	9-3-47	0.0	"
	9-3-47	0.1	"
K-305-8 Line Recorder Station	9-4-47	0.0	"
special operation in progress	9-4-47	0.0	"
K-303-5 Cell #7 seal change,			
pump 5A	9-4-47	0.0	"
	9-4-47	0.1	"
	9-4-47	0.0	"

H. J. Culbert  
H. J. Culbert

Approved:

W. C. Hartman  
W. C. Hartman

JHP/nf

R E S T R I C T E D

77



R E S T R I C T E D

CASCADE SERVICES DEPARTMENT

PROCESS LABORATORY

RADIATION SURVEY

HEALTH SURVEY REPORT

Date of Issue September 5, 1947

DISTRIBUTION LIST

Mr. L. G. Bamer  
Mr. S. C. Barnett  
Dr. C. K. Beck  
Dr. M. J. Costello  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Dr. F. W. Hurd  
Mr. J. A. Marshall

Mr. H. M. Prouss  
Mr. M. P. Schwann  
Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. S. Viener ✓  
Mr. L. C. Willson  
File

R E S T R I C T E D

RESTRICTED

HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location: K-303-7

Date: September 4, 1947

8-25-47 Beta-gamma determinations on the heaters and reactors in the Conversion Room in K-1301 were all zero.

All beta-gamma determinations made in the survey in K-1069 were zero.

8-26-47 All of the beta-gamma measurements made on the cylinders and carbon traps in K-631 were zero.

In K-131 beta-gamma measurements on the cylinders varied from 0.011 to 0.014 and averaged 0.013 R/8 hours; all measurements on the carbon traps in K-131 were zero.

8-27-47 In the K-1301 Conversion Room beta-gamma readings on the reactors and heaters were all zero.

In the decontamination room in K-1303 beta-gamma measurements on the decontamination tanks, work bench, and tool table varied from 0.000 to 0.038 with an average of 0.005 R/8 hours.

8-28-47 In K-631 beta-gamma determinations on the cylinders and carbon traps were all zero.

Beta-gamma measurements on the cylinders in K-131 ranged from 0.005 to 0.012 and averaged 0.009 R/8 hours.

8-29-47 Beta-gamma measurements on the decontamination tanks, work bench, and tool table in the decontamination room in K-1303 varied from 0.000 to 0.055 with an average of 0.006 R/8 hours.

In the conversion room in K-1301 beta-gamma measurements on the heaters and reactors were all zero.

Air samples of air-borne alpha-active dusts taken during the week were as follows:

K-306-7 P. W. Station	8-25-47	0.0 Alpha counts/min/ft <sup>3</sup>
	8-26-47	0.3 "
	8-27-47	0.05 "
	8-28-47	0.4 "
	8-29-47	0.1 "

Walt! Please bring us  
up to-date on this  
location.

RESTRICTED

R E S T R I C T E D

-2-

K-1405 Laboratory	8-25-47	0.0	Alpha counts/min/ft <sup>3</sup>
K-1405 Downstairs Room	8-25-47	0.0	"
K-1401 Conditioning Laboratory	8-25-47	0.0	"
K-1301 Outside weighing room	8-25-47	0.0	"
K-1303 Decontamination Room	8-25-47	0.3	"
	8-27-47	1.6	"
K-1410 Near carbon-alumina separator	8-26-47	0.1	"
K-631 near draw-off manifold	8-26-47	0.0	"
K-131 near vaporization baths	8-26-47	0.1	"
K-1401 retubing area	8-26-47	0.0	"
K-1401 AC pump shop	8-26-47	0.0	"
F-01 in work area	8-27-47	0.0	"
	8-27-47	0.1	"
	8-27-47	1.4	"
K-305-4 Cell #7 seal change, Pump 1B	8-28-47		
Seal being removed and deposit of material between seal and back plate being removed		13.2	Alpha counts/min/ft <sup>3</sup>
Seal being replaced		0.2	"
Bearing being replaced		0.2	"
Duration of operation		1.0	"

H J Culbert

H. J. Culbert

Approved: W. C. Hartman

W. C. Hartman

JHP/nf

R E S T R I C T E D 80

RESTRICTED

CASCADE SERVICES DEPARTMENT

PROCESS LABORATORY

RADIATION GROUP

HEALTH SURVEY REPORT

Date of Issue August 28, 1947

DISTRIBUTION LIST

Mr. L. G. Bamer  
Mr. S. C. Barnett  
Dr. C. K. Beck  
Dr. M. J. Costello  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Dr. F. W. Hurd  
Mr. J. A. Marshall

Mr. H. M. Preuss  
Mr. M. F. Schwenn  
Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. S. Visnor ✓  
Mr. L. C. Willson  
File

RESTRICTED

RESTRICTED

HEALTH SURVEY REPORT

To: Mr. G. T. E. Sheldon  
Location: K-303-7

Date: August 28, 1947

8-18-47 Beta-gamma measurements on the decontamination tanks, work bench, and tool table in the decontamination room in K-1303 ranged from 0.000 to 0.018 and averaged 0.002 R/8 hours.

8-19-47 All beta-gamma measurements on the cylinders and carbon traps in K-631 registered zero.

On the cylinders at K-131 beta-gamma measurements varied from 0.007 to 0.018 and averaged 0.012 R/8 hours.

8-20-47 In the conversion room in K-1301, beta-gamma measurements on the heaters and reactors were all zero.

In the decontamination room in K-1303, beta-gamma measurements on the decontamination tanks ranged from 0.000 to 0.007 with an average of 0.002 R/8 hours.

8-21-47 In K-631 all beta-gamma measurements on cylinders and carbon traps were zero.

In K-131 beta-gamma measurements on the cylinders varied from 0.000 to 0.018 with an average of 0.008 R/8 hours.

8-22-47 Beta-gamma measurements on the heaters and reactors in the conversion room in K-1301 were all zero.

In the K-1303 decontamination room beta-gamma measurements on the work bench and tool table were all zero and the measurements on the decontamination tanks ranged from 0.000 to 0.028 with an average of 0.006 R/8 hours.

Air samples taken during the week of air-borne alpha-active dusts were as follows:

K-306-7 P.W. Station	8-18-47	54.9	Alpha counts/min/ft <sup>3</sup>
	8-19-47	7.3	"
	8-20-47	6.6	"
	8-21-47	1.8	"
	8-22-47	0.1	"

RESTRICTED

RESTRICTED

-2-

K-1301 outside weighing room	8-18-47	0.7	Alpha counts/min/ft <sup>3</sup>
	8-20-47	0.2	"
	8-22-47	0.1	"
K-1303 decontamination room	8-18-47	0.5	"
	8-20-47	0.2	"
	8-22-47	0.2	"
K-1401 conditioning Laboratory	8-18-47	0.1	"
K-1410 near carbon-alumina separator	8-19-47	0.1	"
	8-21-47	0.0	"
K-631 near draw-off manifold	8-19-47	0.0	"
	8-21-47	0.1	"
K-131 near vaporization baths	8-19-47	0.1	"
	8-21-47	0.1	"
F-01 in work area	8-20-47	0.9	"
	8-20-47	0.6	"
	8-20-47	0.6	"
K-1401 retubing area	8-21-47	0.0	"
K-1401 AC pump shop	8-21-47	0.1	"
K-1405 downstairs room	8-22-47	0.1	"
K-1405 laboratory	8-22-47	0.1	"

H. J. Culbert

H. J. Culbert

Approved:

W. C. Hartman

W. C. Hartman

JHP/nf

RESTRICTED

83

RESTRICTED

CASCADE SERVICES DEPARTMENT

RADIATION GROUP

HEALTH SURVEY REPORT

Date of Issue August 21, 1947

DISTRIBUTION LIST

Mr. L. G. Bamer  
Mr. S. C. Barnett  
Mr. C. K. Beck  
Dr. M. J. Costello  
Mr. W. C. Hartman  
Mr. A. P. Huber  
Dr. F. W. Hurd  
Mr. J. A. Marshall

Mr. H. M. Preuss  
Mr. M. F. Schwann  
Mr. M. P. Seyfried  
Mr. G. T. E. Sheldon  
Mr. B. Speyers  
Mr. S. Visner ✓  
Mr. L. C. Willson  
File

RESTRICTED

RESTRICTED

RADIATION SURVEY GROUP

HEALTH SURVEY REPORT

Week Ending August 15th, 1947

8-11-47 Beta-gamma readings made in K-1301 at the cold trap and heaters in the Oxide Conversion Room ranged from 0.000 to 0.014 and averaged 0.004 R/8 hours.

Beta-gamma readings taken on the decontamination tanks, work bench, and tool table in the decontamination room in K-1303 varied from 0.000 to 0.002, averaging 0.005 R/8 hours.

8-12-47 The shipping cylinders at K-131 had beta-gamma readings which ran from 0.004 to 0.018 and averaged 0.009 R/8 hours.

Beta-gamma measurements on the cylinders and traps at K-631 were zero.

8-13-47 In the decontamination room in K-1303, beta-gamma readings on the decontamination tanks, work bench, and tool table ran from 0.000 to 0.058 averaging 0.005 R/8 hours.

Beta-gamma measurements on the cold traps and reactors in the Conversion Room in K-1301 were zero.

8-14-47 In K-131 beta-gamma readings on the shipping cylinders varied from 0.007 to 0.014 and averaged 0.012 R/8 hours.

The beta-gamma readings on the cylinders in K-631 were zero.

8-15-47 In the decontamination room in K-1303, beta-gamma readings ranged from 0.0001 to 0.0138 with an average of 0.0059 R/8 hours.

Air samples taken during the week for air-borne alpha-active dusts were as follows:

K-306-7	P. W. Station	8-11-47	0.0	Alpha counts/min/100
		8-12-47	11.0	"
		8-13-47	0.6	"
		8-14-47	2.4	"
		8-15-47	61.6	"

RESTRICTED



RESTRICTED

-2-

K-1303 Decontamination Room	8-11-47	0.4	Alpha counts/min/ft <sup>3</sup>
	8-13-47	6.8	"
	8-15-47	0.9	"
K-1301 Outside weighing room door	8-11-47	0.1	"
	8-13-47	9.4	"
	8-15-47	0.1	"
K-1401 Retubing Area	8-11-47	0.0	"
	8-14-47	0.0	"
K-1401 A.C. Pump Shop	8-11-47	0.0	"
	8-14-47	0.1	"
K-1410 near carbon-alumina separator	8-12-47	0.0	"
	8-14-47	0.0	"
K-131 near vaporization baths	8-12-47	0.1	"
	8-14-47	0.0	"
K-631 near draw-off manifold	8-12-47	0.1	"
	8-14-47	0.0	"
F-01 in work area	8-13-47	0.3	"
	8-13-47	0.0	"
	8-13-47	0.0	"
X-309-3 Intersectional Cell	8-15-47	1.3	"
During special operation	8-15-47	0.1	"
	8-15-47	0.6	"
	8-15-47	0.4	"
	8-15-47	0.2	"

H. J. Culbert

H. J. Culbert

Approved:

W. C. Hartman

W. C. Hartman

JHP/nf

RESTRICTED